



FLOOR PLAN ABOVE ELEVATION 230.80
1:100

DRAWING NOTES

- ① EXISTING MAIN 4160V VACUUM BREAKER
- ② EXISTING SCHNEIDER VACUUM BREAKER TO BE SET UP AND MADE READY FOR SERVICE.
- ③ REFER TO DRAWINGS WD-E0411, WD-E0412, WD-E0413 AND WD-E0414 FOR REPLACEMENT OF EXISTING AND NEW SWITCHGEAR.
- ④ SUPPLY AND INSTALL THREE (3) 15A-1P BREAKERS IN PANEL 'C' FOR CONTROL PANELS CP-D21, LCP-D11 AND LCP-D12.
- ⑤ SUPPLY AND INSTALL ONE (1) 30A-1P BREAKER AND TWO (2) 15A-1P BREAKERS IN UPS PANEL FOR CONTROL PANELS CP-D21, LCP-D11 AND LCP-D12.

GENERAL NOTES

- 1. COORDINATE WITH OTHER TRADES TO PREVENT CONFLICTS.
- 2. USE PVC JACKETED TECK CABLE FOR ALL POWER WIRING.
- 3. ALL CONDUIT TO BE 21mmØ MINIMUM UNLESS OTHERWISE NOTED.



B.M. ELEV.			
00	ISSUED FOR TENDER	07/03/19	ERC
NO.	REVISIONS	DATE	BY

 Frederickson Cooper ARCHITECTS		 A Teck International Ltd. Company	
DESIGNED BY	GSN	CHECKED BY	PS
DRAWN BY	ERC	APPROVED BY	AHL
SCALE:	AS SHOWN	RELEASED FOR CONSTRUCTION BY:	R. SOROKOWSKI
DATE	2006/11/09	DATE	2007/03/19

ENGINEER'S SEAL
ORIGINAL SIGNED BY
P. STRYK
2007/03/19
CONSULTANT DRAWING NO.
WD-E0113

THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION	
WATER TREATMENT PLANT DEACON BOOSTER PUMP STATION UPGRADE	CITY FILE NUMBER SHEET OF
ELECTRICAL UPPER LEVEL PLAN LAYOUT ABOVE 230.8m	CITY DRAWING NUMBER 1-060D-A-E013-001-00D