

CONSTRUCTION NOTES:

ALL EXCAVATION AND GRANULAR BASE WORK SHALL BE COMPLETED IN ACCORDANCE WITH CW 3110 - R7

ASPHALT WORK WILL BE DONE IN ACCORDANCE WITH CW 3410 - R5

CONCRETE WORK WILL BE DONE IN ACCORDANCE WITH CW 3310 - R8

GRANUALR BASE SHALL BE INSPECTED AND APPROVED BY THE CITY OF WINNIPEG PRIOR TO ASPHALT INSTALLATION

ALL GRADES TO BE CONFIRMED WITH CITY OF WINNIPEG PRIOR TO CONSTRUCTION

IF SOFT SPOTS AND/OR FROST SUSCEPTIBLE SILT DEPOSITS ARE ENCOUNTERED DURING THE COURSE OF COMMON EXCAVATION , CONSTRUCTION TRAFFIC SHALL BE RESTRICTED. THE SILT AND SOFT SPOTS SHALL BE SUBEXCAVATED TO THE LOWER LIMIT OF UNSUITABLE MATERIAL OR DO A DEPTH OF 600 mm BELOW THE ELEVATION OF THE BOTTOM SUBBASE AND REPLACED WITH A 600 mm THICK LAYER OF 100 mm DOWN DURABLE CRUSHED LIMESTONE IN ACCORDANCE WITH SPECIFICATION CW 3110 - R7. THE CONTRACTOR MUST OBTAIN THE CITY OF WINNIPEG'S APPROVAL PRIOR TO COMMENCEMENT OF THIS WORK.

DETERMINE LOCATION OF ALL UNDERGROUND UTILITIES AND OBTAIN CLEARENCES PRIOR TO CONSTRUCTION. UNDERGROUND INFORMATION IS BASED ON THE BEST INFORMATION AVAILABLE. THE CITY OF WINNIPEG MAKES NO GUARANTEE TO THE CORRECTNESS OF THE INFORMATION.

CONTRACTOR RESPONSIBLE TO CLEAN UP SITE AFTER CONSTRUCTION. THE CONTRACTOR SHALL RESTORE ALL AREAS OF THE SITE BEYOND THE ESTABLISHED LIMIT OF WORK TO AS GOOD OR BETTER THAN THE ORIGINAL CONDITION.

ALL MEASUREMENTS AND DIMENSIONS ARE IN METRIC.

ALL ELEVATIONS SHOWN ARE GEODETIC ELEVATIONS - ADD 200.00

