



455-2006 ADDENDUM 1

PLAYGROUND REDEVELOPMENT AT MACHRAY PARK

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: August 22, 2006
BY: Coleen Groening
TELEPHONE NO. (204) 986-2491

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20060821

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

- Revise: E4.3 (a) to read: Excavation will be paid for at the contract unit price measured by the cubic meter for the "Excavation for extension of play area (0.10 M depth)".
- Revise: E6.1 (a) to read: This specification shall cover the supply and installation of new Play Stone to achieve 300 mm depth of safety surface in Play area-A and extended play area.
- Revise: E6.3 (a) to read: New Play Stone shall be installed in addition to the existing Play Stone in Play area-A to achieve a minimum depth of 300 mm and depths over 300mm will not be paid.
- Revise E7.6 (b) to read: Foundations and Removal and re-installation of existing safety surface material needed to complete the work shall be considered incidental to and payment to be included with the prices for supply and installation of play structure, swings, and other play equipment components.