



Environmental Division

PRELIMINARY RESULTS

OHG CONSULTING INC

ATTN: DOUG WYLIE

121 KEEDIAN DRIVE

EAST ST PAUL MB R3E 0K3

Reported On: 06-SEP-06 11:16 AM

Lab Work Order #: **L429328**

Date Received: **05-SEP-06**

Project P.O. #:

Job Reference: 151 HIGGINS

Legal Site Desc:

CofC Numbers:

Other Information:

Comments: "Other" fibres were mould filaments.

APPROVED BY: _____

BARB BAYER

Project Manager

THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL WITHOUT THE WRITTEN AUTHORITY OF THE LABORATORY.
ALL SAMPLES WILL BE DISPOSED OF AFTER 30 DAYS FOLLOWING ANALYSIS. PLEASE CONTACT THE LAB IF YOU
REQUIRE ADDITIONAL SAMPLE STORAGE TIME.

ALS LABORATORY GROUP ANALYTICAL REPORT

Sample Details/Parameters	Result	Qualifier*	D.L.	Units	Extracted	Analyzed	By	Batch
L429328-1 151 HIGGINS - CORK PLASTIC								
Sampled By: OHG - DW on 05-SEP-06								
Matrix: BULK								
Bulk Asbestos Content								
Asbestos	<1		1	%		06-SEP-06	BMG	R438503
Other Fibres	<1		1	%		06-SEP-06	BMG	R438503
Other Non Fibrous: Tar	100		1	%		06-SEP-06	BMG	R438503
Note: No asbestos fibres were observed.								
* Refer to Referenced Information for Qualifiers (if any) and Methodology.								

Reference Information

Methods Listed (if applicable):

ALS Test Code	Matrix	Test Description	Preparation Method Reference(Based On)	Analytical Method Reference(Based On)
ASBESTOS-WP	Bulk	Bulk Asbestos Content		NIOSH 9002-Polarized Light Microscopy

Bulk samples are examined under a stereoscopic microscope. Individual fibers or fibre bundles are mounted in refractive index liquids and are observed under a polarized light microscope with a special dispersion staining objective. The dispersion staining colours are compared to reference samples of known asbestiforms.

Polarized microscopy is not a definitive technique for negative results for non friable organically bound material (i.e.floor tiles).

** Laboratory Methods employed follow in-house procedures, which are generally based on nationally or internationally accepted methodologies.

Chain of Custody numbers:

The last two letters of the above test code(s) indicate the laboratory that performed analytical analysis for that test. Refer to the list below:

Laboratory Definition Code	Laboratory Location	Laboratory Definition Code	Laboratory Location
WP	ALS LABORATORY GROUP - WINNIPEG, MANITOBA, CANADA		

GLOSSARY OF REPORT TERMS

Surr - A surrogate is an organic compound that is similar to the target analyte(s) in chemical composition and behavior but not normally detected in environmental samples. Prior to sample processing, samples are fortified with one or more surrogate compounds.

The reported surrogate recovery value provides a measure of method efficiency. The Laboratory control limits are determined under column heading D.L.

mg/kg (units) - unit of concentration based on mass, parts per million.

mg/L (units) - unit of concentration based on volume, parts per million.

< - Less than.

D.L. - The reporting limit.

N/A - Result not available. Refer to qualifier code and definition for explanation.

Test results reported relate only to the samples as received by the laboratory.

UNLESS OTHERWISE STATED, ALL SAMPLES WERE RECEIVED IN ACCEPTABLE CONDITION.

UNLESS OTHERWISE STATED, SAMPLES ARE NOT CORRECTED FOR CLIENT FIELD BLANKS.

Although test results are generated under strict QA/QC protocols, any unsigned test reports, faxes, or emails are considered preliminary.

ALS Laboratory Group has an extensive QA/QC program where all analytical data reported is analyzed using approved referenced procedures followed by checks and reviews by senior managers and quality assurance personnel. However, since the results are obtained from chemical measurements and thus cannot be guaranteed, ALS Laboratory Group assumes no liability for the use or interpretation of the results.