



ADDENDUM NO. 1 BID OPPORTUNITY NO. 492-2006

**DEMOLITION OF 151 HIGGINS AVE. – MANITOBA COLD STORAGE –
EAST BUILDING**

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: September 14, 2006
BY: Jeff Dibley/j
TELEPHONE NO. (204) 986-2889

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20040901

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid Submission non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 12:00 noon, Winnipeg time, September 20, 2006.

PART D – SUPPLEMENTAL CONDITIONS

Revise: D15.1 (b) to read: Entire building superstructure demolished by December 31, 2006

Revise: D16.1 to read: The Contractor shall achieve Substantial Performance by January 31, 2007.

Revise: D17.1 to read: The Contractor shall achieve Total Performance by February 28, 2007.

PART E – SPECIFICATIONS

ADD: E5.7 The existing mastic adhesive on the cork insulation was submitted to lab for testing. Test results for asbestos content of the mastic adhesive is less than 1%. The report on results is attached in file 492-2006 Addendum 1 Cork Mastic Test Results. The mastic adhesive will not be required to be removed as part of the environmental abatement process prior to demolition.