




REV.	CABLE TAG	CABLE SPECIFICATIONS	LENGTH (m)	FROM	TO	DESCRIPTION	REMARKS
0	C-LCP-P38-C01	4-Pair #24 AWG - Cat 5E		CP-P32 DAF Basins 5-8 Control Panel	LCP-P38 DAF Basin 8 VFD Control Panel	DAF Basin 8 VFD Control	In Contract 742-2005.
0	C-LCP-R21-C01	1-Coaxial RG-6		LCP-R21A Residuals Communication Panel	LCP-R21	Residuals Remote I/O	In Contract 742-2005.
0	C-LCP-S11-C01	1-Coaxial RG-6		LCP-S11A Bulk Chemical Communication Panel	LCP-S11	Bulk Chemical Remote I/O	In Contract (Bulk Chem).
0	C-LCP-T11-C01	1-Coaxial RG-6		LCP-T11A Clearwell Communication Panel	LCP-T11	Clearwell Remote I/O	In Contract 498-2006.
0	C-WTPAPRTR01-C01	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPAPRTR01	Router/Gateway Network Cable	In Contract 742-2005.
0	C-WTPSVES01-C01	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPSVES01	Engineering Workstation Plant Control Network Cable	In Contract 742-2005.
0	C-WTPSVES01-C02	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPSVES01	Engineering Workstation Plant Monitoring Network Cable	In Contract 742-2005.
0	C-WTPSVHIS01-C01	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPSVHIS01	Primary Historical Server Network Cable	In Contract 742-2005.
0	C-WTPSVHIS02-C01	4-Pair #24 AWG - Cat 5E		CP-H32A Backup Server Room Communication Panel	WTPSVHIS02	Standby Historical Server Network Cable	In Contract 742-2005.
0	C-WTPSVR01-C01	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPSVR01	Primary Real Time Server Plant Control Network Cable	In Contract 742-2005.
0	C-WTPSVR02-C01	4-Pair #24 AWG - Cat 5E		CP-H32A Backup Server Room Communication Panel	WTPSVR02	Standby Real Time Server Plant Control Network Cable	In Contract 742-2005.
0	C-WTPSVR02-C02	4-Pair #24 AWG - Cat 5E		CP-H32A Backup Server Room Communication Panel	WTPSVR02	Standby Real Time Server Plant Monitoring Network Cable	In Contract 742-2005.
0	C-WTPWSC11 01-C01	4-Pair #24 AWG - Cat 5E		CP-C11A Polymer Communication Panel	WTPWSC11 01	Local Operator Workstation at CP-C11	In Contract 742-2005.
0	C-WTPWSCR01-C01	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPWSCR01	Operator Workstation 01 Network Cable	In Contract 742-2005.
0	C-WTPWSCR02-C01	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPWSCR02	Operator Workstation 02 Network Cable	In Contract 742-2005.
0	C-WTPWSCR03-C01	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPWSCR03	Operator Workstation 03 Network Cable	In Contract 742-2005.
0	C-WTPWSCR04-C01	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPWSCR04	Operator Workstation 04 Network Cable	In Contract 742-2005.

NOTES:  <p>Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2006.</p>	B.M. ELEV.		 		ENGINEER'S SEAL ORIGINAL SIGNED BY S.W. TORMEY 2006/03/29 CONSULTANT DRAWING NO. WH-A0703	THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION					
	6	498-2006 ADDENDUM 6	06/10/13	BT				DESIGNED BY	SWT	CHECKED BY	SWT
	5	498-2006 ADDENDUM 2	06/09/22	BT				DRAWN BY	SWT	APPROVED BY	AHL
	4	FOR CONSTRUCTION	06/07/28	BT		SCALE:		RELEASED FOR CONSTRUCTION BY:			
	3	GENERAL REVISIONS	06/07/13	BT		NTS		R. SOROKOWSKI			
	2	742-2005 ADDENDUM 13	06/06/30	BT		DATE	2006/03/29	DATE	2006/03/29		
1	742-2005 ADDENDUM 6	06/05/25	SWT					WATER TREATMENT PLANT PLANT UTILITIES MECHANICAL AND ELECTRICAL AUTOMATION / I AND C PLANT COMMUNICATION CABLES CABLE LIST			
0	ISSUED FOR TENDER	06/03/29	SWT					CITY FILE NUMBER SHEET 3 OF 11 CITY DRAWING NUMBER 1-0601H-K-A0703-001-06B			
NO.	REVISIONS	DATE	BY								

Friday, October 13, 2006