

DRAWING NOTES

- 1 ENTIRE O/A DUCT FROM THE CEILING TO AHU-H242A SHALL BE THERMALLY INSULATED. PROVIDE INTAKE GRAVITY HOOD W/ ROOF CURB ON TOP OF ROOF.
- 2 R/A DUCT.
- 3 ENSURE ADEQUATE CLEARANCE TO ALLOW PULLING OUT COILS. ALSO, ALLOW ADEQUATE CLEARANCE FOR GENERAL UNIT MAINTENANCE.
- 4 PROVIDE THERMOSTAT MOUNTED ON CONCRETE COLUMN, 1500-mm ABOVE INSIDE FLOOR LEVEL. SEE STRUCTURAL FOR COLUMN LOCATION.
- 5 FIRE EXTINGUISHER SHALL BE MOUNTED AS PER LOCAL CODES AND REGULATIONS.
- 6 50mm THICK INSULATION FROM LOUVER TO END OF DUCT
- 7 MONORAIL PATH. ENSURE DUCT IS ABOVE THE MONORAIL.
- 8 VALVE FLOOR BOX. TO CONTROL CLEARWELL WASHDOWN PIPING BELOW.

- 9 1000 SANITARY DRAIN MOUNTED AGAINST AIR SHAFT WALL AND SLOPED MINIMUM 1% TOWARDS EXTERIOR WALL. ALLOW FOR EIGHT (8) INSTRUMENT DRAIN CONNECTIONS.
- 10 SEE DRAWING WT-M0002 FOR CONTINUATION. REFER TO STRUCTURAL FOR PENETRATION LOCATION.
- 11) THIS PORTION OF DUCT SHALL RISE ABOVE ELECTRICAL CABLE TRAYS. COORIDINATE WITH ELECTRICAL TO PREVENT CONFLICTS.

GENERAL NOTES

- 1. COORDINATE WITH OTHER TRADES SO AS TO PREVENT CONFLICTS.
- 2. ALL DUCTS SHALL BE PROPERLY SECURED AND SUPPORTED ACCORDING TO APPLICABLE CODES.

ENGINEER'S SEAL CH2MHILL THE CITY OF WINNIPEG ELEV. EarthTech WATER AND WASTE DEPARTMENT Winnipeg ENGINEERING DIVISION Frederickson Cooper ORIGINAL SIGNED BY A. BURACHYNSKY DESIGNED CHECKED WATER TREATMENT PLANT CITY FILE NUMBER Certificate of Authorization TREATED WATER STORAGE APPROVED Earth Tech Canada Inc. 2006/08/30 DRAWN 03 498-2006 ADDENDUM 7 06/10/19 DC BY SHEET OF INLET BUILDING No. 730 Expiry: April 30, 2007 02 | 498-2006 ADDENDUM 6 06/10/17 DC AS SHOWN RELEASED FOR CONSTRUCTION BY: CITY DRAWING NUMBER SCALE: MECHANICAL 01 498-2006 ADDENDUM 3 06/09/28 DC CONSULTANT DRAWING NO. VENTILATION R. SOROKOWSKI 00 ISSUED FOR TENDER 06/08/28 DC 1-0601T-A-M0003-001-03D WT-M0003 PLAN DATE BY DATE 2005/03/15 NO. REVISIONS DATE 2006/08/30