



DRAWING NOTES	
1	PROVIDE PROPER DUCT TRANSITION PIECE.
2	UNDERSIDE OF DUCT SHALL BE MINIMUM 2200mm ABOVE INSIDE FLOOR LEVEL TO ALLOW PROPER HEAD CLEARANCE.
3	ENTIRE O/A DUCT SHALL BE INSULATED WITH 50mm THERMAL INSULATION.
4	ENTIRE RELIEF AIR DUCT SHALL BE INSULATED WITH 50mm THERMAL INSULATION.
5	INTAKE HOOD SHALL INCLUDE A BIRD SCREEN AND MOTORIZED DAMPERS. THROAT SIZE SHALL BE 1050x300.
6	UNDERSIDE OF DUCT TO BE 2200 ABOVE FINISHED FLOOR.

  

GENERAL NOTES	
1.	COORDINATE WITH OTHER TRADES SO AS TO PREVENT CONFLICTS.

<p>Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2007</p>	B.M. ELEV.	<p>Frederickson Cooper ARCHITECTS</p>	<p>A Type International Ltd. Company</p>	ENGINEER'S SEAL	<p>THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION</p>	CITY FILE NUMBER		
				DESIGNED BY DC		CHECKED BY AB	ORIGINAL SIGNED BY	SHEET OF
				DRAWN BY DC		APPROVED BY AHL	A. BURACHYNSKY	WATER TREATMENT PLANT TREATED WATER STORAGE INLET BUILDING
				SCALE: AS SHOWN		RELEASED FOR CONSTRUCTION BY: R. SOROKOWSKI	2006/08/30	MECHANICAL VENTILATION SECTIONS
	NO. REVISIONS	DATE	BY	DATE	CONSULTANT DRAWING NO. WT-M0004			
		2005/03/15		2006/08/30				