



1
-
GENERATOR ROOM COOLING AND VENTILATION FOR GN-E902A
N.T.S.

NOTES:
 ① BAS CONTROLLER #2.
 I/O POINTS WIRED TO GENERATOR DDC(BAS) CONTROL PANEL AS PER SPEC. SECTIONS 15900, 15901, 15902. TYPICAL FOR EACH OF 3 GENERATORS.

APEGM
 Certificate of Authorization
 Earth Tech Canada Inc.
 No. 730 Expiry: April 30, 2007

B.M. ELEV.					
DESIGNED BY	AB	CHECKED BY	AMA, PVL		
DRAWN BY	DJP	APPROVED BY	AHL		
SCALE:	AS NOTED	RELEASED FOR CONSTRUCTION BY:	R. SOROKOWSKI		
00 ISSUED FOR TENDER	06/08/28	LJW			
NO. REVISIONS	DATE	BY	DATE	2006/06/15	DATE
				2006/08/30	

ENGINEER'S SEAL
 ORIGINAL SIGNED BY
 A. BURACHYNSKY
 2006/08/30
 CONSULTANT DRAWING NO.
 WG-H0503

THE CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT
 ENGINEERING DIVISION

WATER TREATMENT PLANT
 STANDBY POWER GENERATOR

MECHANICAL
 GN-E902A
 COOLING AND VENTILATION SCHEMATICS

CITY FILE NUMBER
 SHEET OF
 CITY DRAWING NUMBER
 1-0601G-G-H0503-001-000