



2 EMERGENCY EGRESS HUT FLOOR PLAN- TYPICAL OF 4
1:50

1 INLET BUILDING FLOOR PLAN AT ELEV: 238.700
1:50

NOTE:
 -SEAL ALL CONTROL JOINTS IN FINISH CONCRETE FLOOR TOPPING WITH BACKER ROD AND SEALANT TO PREVENT WATER PENETRATION & DAMAGE OF SLAB RIGID INSULATION. PROVIDE 4mm THK S.S. FLOOR JOINT COVER PLATE, TYP.
 -FOR ALUMINUM COVERS, SEE STRUCTURAL

B.M. ELEV.			ENGINEER'S SEAL	THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION	
	DESIGNED BY BS	CHECKED BY MK	ORIGINAL SIGNED BY N. COOPER	WATER TREATMENT PLANT TREATED WATER STORAGE INLET BUILDING	
	DRAWN BY GGP/WC	APPROVED BY AHL	06/08/30	CITY FILE NUMBER	
	SCALE: AS NOTED	RELEASED FOR CONSTRUCTION BY: R. SOROKOWSKI		SHEET OF	
00 ISSUED FOR TENDER 06/08/28 WDB	DATE 05/04/04	DATE 06/08/30	CONSULTANT DRAWING NO. WT-B0002	CITY DRAWING NUMBER 1-0601T-A-B0002-001-000	
NO. REVISIONS	DATE	BY			