



DRAWING NOTES

- 1 PROVIDE PROPER DUCT TRANSITION PIECE.
- 2 UNDERSIDE OF DUCT SHALL BE MINIMUM 2200mm ABOVE INSIDE FLOOR LEVEL TO ALLOW PROPER HEAD CLEARANCE.
- 3 ENTIRE O/A DUCT SHALL BE INSULATED WITH 50mm THERMAL INSULATION.
- 4 ENTIRE RELIEF AIR DUCT SHALL BE INSULATED WITH 50mm THERMAL INSULATION.
- 5 INTAKE HOOD SHALL INCLUDE A BIRD SCREEN AND MOTORIZED DAMPERS. THROAT SIZE SHALL BE 1050x300.
- 6 UNDERSIDE OF DUCT TO BE 2200 ABOVE FINISHED FLOOR.

GENERAL NOTES

- 1. COORDINATE WITH OTHER TRADES SO AS TO PREVENT CONFLICTS.

 Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2007	B.M. ELEV.	 Frederickson Cooper ARCHITECTS	 A Tyco International Ltd. Company	ENGINEER'S SEAL	 THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION	CITY FILE NUMBER			
				DESIGNED BY DC		CHECKED BY AB	ORIGINAL SIGNED BY	SHEET OF	
				DRAWN BY DC		APPROVED BY AHL	A. BURACHYNSKY	WATER TREATMENT PLANT TREATED WATER STORAGE INLET BUILDING	CITY DRAWING NUMBER
				SCALE: AS SHOWN		RELEASED FOR CONSTRUCTION BY: R. SOROKOWSKI	2006/08/30	MECHANICAL VENTILATION SECTIONS	1-06011-A-M0004-001-000
	00 ISSUED FOR TENDER 06/08/28 DC			CONSULTANT DRAWING NO. WT-M0004					
	NO. REVISIONS	DATE BY	DATE	2005/03/15	DATE	2006/08/30			