

POINT	POINT DESCRIPTION	ASSOCIATED DEVICE	CONTROLLER ID																							
			05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26		
AO-1	PROPORTIONAL MIXED AIR DAMPER	ADVANCED CONTROL TECH. DRN2-0/135-3			X	X	X							X					X	X		X		X		
AO-2	PROPORTIONAL GAS VALVE	ADVANCED CONTROL TECH. DRN2-0/135-3			X	X	X						X					X	X		X		X			
BO-1	BLOWER START/STOP	24VAC 2PDT RELAY			X	X	X						X					X	X		X		X			
BO-2	HEATING ENABLE/DISABLE	24VAC 2PDT RELAY			X	X	X						X					X	X		X		X			
BO-3	(SPARE)																									
BO-4	(SPARE)																									
BO-5	(SPARE)																									
BO-6	(SPARE)																									
AI-1	(SPARE)																									
AI-2	(SPARE)																									
AI-3	SPACE TEMPERATURE	TE-6000-4 1000 OHM RTD			X	X	X						X					X	X		X		X			
AI-4	SUPPLY AIR TEMPERATURE	TE-6000-4 1000 OHM RTD			X	X	X						X					X	X		X		X			
AI-5	(SPARE)																									
AI-6	(SPARE)																									
BI-1	BLOWER STATUS	CURRENT SENSING SWITCH			X	X	X						X					X	X		X		X			
BI-2	FLAME FAILURE	DRY CONTACT ON FLAME FAILURE RELAY			X	X	X						X					X	X		X		X			
BI-3	OVERHEAD DOOR STATUS "A"	DRY CONTACT ON OVERHEAD DOOR			⊗		⊗						⊗						⊗				⊗			
BI-4	OVERHEAD DOOR STATUS "B"	DRY CONTACT ON OVERHEAD DOOR			⊗		⊗						⊗						⊗				⊗			

⊗ TO BE WIRED AT FUTURE DATE.

FORT ROUGE GARAGE STORAGE GARAGE UNIT CONTROLLER DDC CNTLR POINT LAYOUT	REVISION 2 DRAWING NO. 1501-09D-ii
--	---