

24x36 24x368  
File Name: P:\Projects\2006\06-0107-08\Elect\Drawings\06-0107-08E06.dwg - Tab: E6 Plotted By: G.Nelson 10/23/2006 [Mon 1:51pm]  
24x36 / PLOT SCALE: 1"=1'

SUPPLY: 120/208V 3 $\phi$ 4W MAINS AMPACITY: 100A INCOMING: <input type="checkbox"/> BREAKER <input checked="" type="checkbox"/> LUGS MAIN BREAKER REQUIRED: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO MAIN BREAKER AMPS: BUS MATERIAL: <input checked="" type="checkbox"/> COPPER <input type="checkbox"/> ALUMINUM BUS AND BREAKER RATING: ___ kA (SYM.) I.C.	NAME PLATE: <b>PANEL</b> <b>EM-208-A</b>	LOCATION: ELECTRICAL ROOM MOUNTING: <input checked="" type="checkbox"/> SURFACE <input type="checkbox"/> FLUSH MANUFACTURER: SQUARE D MODEL NO: - BREAKER: <input type="checkbox"/> PLUG-IN <input type="checkbox"/> BOLT-ON BREAKER TYPE: -
CCT	VA P BKR A B C BKR P VA	CCT
1	-	22
2	-	23
3	-	24
4	-	25
5	-	26
6	-	27
7	-	28
8	-	29
9	-	30
10	-	31
11	-	32
12	-	33
13	-	34

SUPPLY: 120/208V 3 $\phi$ 4W MAINS AMPACITY: 100A INCOMING: <input type="checkbox"/> BREAKER <input checked="" type="checkbox"/> LUGS MAIN BREAKER REQUIRED: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO MAIN BREAKER AMPS: BUS MATERIAL: <input checked="" type="checkbox"/> COPPER <input type="checkbox"/> ALUMINUM BUS AND BREAKER RATING: ___ kA (SYM.) I.C.	NAME PLATE: <b>PANEL</b> <b>EM-208-B</b>	LOCATION: ELECTRICAL ROOM MOUNTING: <input checked="" type="checkbox"/> SURFACE <input type="checkbox"/> FLUSH MANUFACTURER: SQUARE D MODEL NO: - BREAKER: <input type="checkbox"/> PLUG-IN <input type="checkbox"/> BOLT-ON BREAKER TYPE: -
CCT	VA P BKR A B C BKR P VA	CCT
1	-	22
2	-	23
3	-	24
4	-	25
5	-	26
6	-	27
7	-	28
8	-	29
9	-	30
10	-	31
11	-	32
12	-	33
13	-	34

SUPPLY: 120/208V 3 $\phi$ 4W MAINS AMPACITY: 100A INCOMING: <input type="checkbox"/> BREAKER <input checked="" type="checkbox"/> LUGS MAIN BREAKER REQUIRED: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO MAIN BREAKER AMPS: BUS MATERIAL: <input checked="" type="checkbox"/> COPPER <input type="checkbox"/> ALUMINUM BUS AND BREAKER RATING: ___ kA (SYM.) I.C.	NAME PLATE: <b>PANEL</b> <b>EM-208-C</b>	LOCATION: ELECTRICAL ROOM MOUNTING: <input checked="" type="checkbox"/> SURFACE <input type="checkbox"/> FLUSH MANUFACTURER: SQUARE D MODEL NO: - BREAKER: <input type="checkbox"/> PLUG-IN <input type="checkbox"/> BOLT-ON BREAKER TYPE: -
CCT	VA P BKR A B C BKR P VA	CCT
1	-	13
2	-	14
3	-	15
4	-	16
5	-	17
6	-	18
7	-	19
8	-	20
9	-	21
10	-	22
11	-	23
12	-	24

SUPPLY: 120/208V 3 $\phi$ 4W MAINS AMPACITY: 100A INCOMING: <input type="checkbox"/> BREAKER <input checked="" type="checkbox"/> LUGS MAIN BREAKER REQUIRED: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO MAIN BREAKER AMPS: BUS MATERIAL: <input checked="" type="checkbox"/> COPPER <input type="checkbox"/> ALUMINUM BUS AND BREAKER RATING: ___ kA (SYM.) I.C.	NAME PLATE: <b>PANEL</b> <b>EM-208-D</b>	LOCATION: ELECTRICAL ROOM MOUNTING: <input checked="" type="checkbox"/> SURFACE <input type="checkbox"/> FLUSH MANUFACTURER: SQUARE D MODEL NO: - BREAKER: <input type="checkbox"/> PLUG-IN <input type="checkbox"/> BOLT-ON BREAKER TYPE: -
CCT	VA P BKR A B C BKR P VA	CCT
1	-	13
2	-	14
3	-	15
4	-	16
5	-	17
6	-	18
7	-	19
8	-	20
9	-	21
10	-	22
11	-	23
12	-	24

SUPPLY: 120/208V 3 $\phi$ 4W MAINS AMPACITY: 100A INCOMING: <input type="checkbox"/> BREAKER <input checked="" type="checkbox"/> LUGS MAIN BREAKER REQUIRED: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO MAIN BREAKER AMPS: BUS MATERIAL: <input checked="" type="checkbox"/> COPPER <input type="checkbox"/> ALUMINUM BUS AND BREAKER RATING: ___ kA (SYM.) I.C.	NAME PLATE: <b>PANEL</b> <b>EM-208-F</b>	LOCATION: ELECTRICAL ROOM MOUNTING: <input checked="" type="checkbox"/> SURFACE <input type="checkbox"/> FLUSH MANUFACTURER: SQUARE D MODEL NO: - BREAKER: <input type="checkbox"/> PLUG-IN <input type="checkbox"/> BOLT-ON BREAKER TYPE: -
CCT	VA P BKR A B C BKR P VA	CCT
1	-	13
2	-	14
3	-	15
4	-	16
5	-	17
6	-	18
7	-	19
8	-	20
9	-	21
10	-	22
11	-	23
12	-	24

SUPPLY: 120/208V 3 $\phi$ 4W MAINS AMPACITY: 100A INCOMING: <input type="checkbox"/> BREAKER <input checked="" type="checkbox"/> LUGS MAIN BREAKER REQUIRED: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO MAIN BREAKER AMPS: BUS MATERIAL: <input checked="" type="checkbox"/> COPPER <input type="checkbox"/> ALUMINUM BUS AND BREAKER RATING: ___ kA (SYM.) I.C.	NAME PLATE: <b>PANEL</b> <b>EM-208-G</b>	LOCATION: ELECTRICAL ROOM MOUNTING: <input checked="" type="checkbox"/> SURFACE <input type="checkbox"/> FLUSH MANUFACTURER: SQUARE D MODEL NO: - BREAKER: <input type="checkbox"/> PLUG-IN <input type="checkbox"/> BOLT-ON BREAKER TYPE: -
CCT	VA P BKR A B C BKR P VA	CCT
1	-	13
2	-	14
3	-	15
4	-	16
5	-	17
6	-	18
7	-	19
8	-	20
9	-	21
10	-	22
11	-	23
12	-	24

SUPPLY: 120/208V 3 $\phi$ 4W MAINS AMPACITY: 200A INCOMING: <input type="checkbox"/> BREAKER <input checked="" type="checkbox"/> LUGS MAIN BREAKER REQUIRED: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO MAIN BREAKER AMPS: BUS MATERIAL: <input checked="" type="checkbox"/> COPPER <input type="checkbox"/> ALUMINUM BUS AND BREAKER RATING: ___ kA (SYM.) I.C.	NAME PLATE: <b>PANEL</b> <b>UPS-208-A</b>	LOCATION: ELECTRICAL ROOM MOUNTING: <input checked="" type="checkbox"/> SURFACE <input type="checkbox"/> FLUSH MANUFACTURER: SQUARE D MODEL NO: - BREAKER: <input type="checkbox"/> PLUG-IN <input type="checkbox"/> BOLT-ON BREAKER TYPE: -
CCT	VA P BKR A B C BKR P VA	CCT
1	-	22
2	-	23
3	-	24
4	-	25
5	-	26
6	-	27
7	-	28
8	-	29
9	-	30
10	-	31
11	-	32
12	-	33
13	-	34
14	-	35
15	-	36
16	-	37
17	-	38
18	-	39
19	-	40
20	-	41
21	-	42

SUPPLY: 120/208V 3 $\phi$ 4W MAINS AMPACITY: 200A INCOMING: <input type="checkbox"/> BREAKER <input checked="" type="checkbox"/> LUGS MAIN BREAKER REQUIRED: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO MAIN BREAKER AMPS: BUS MATERIAL: <input checked="" type="checkbox"/> COPPER <input type="checkbox"/> ALUMINUM BUS AND BREAKER RATING: ___ kA (SYM.) I.C.	NAME PLATE: <b>PANEL</b> <b>UPS-208-B</b>	LOCATION: ELECTRICAL ROOM MOUNTING: <input checked="" type="checkbox"/> SURFACE <input type="checkbox"/> FLUSH MANUFACTURER: SQUARE D MODEL NO: - BREAKER: <input type="checkbox"/> PLUG-IN <input type="checkbox"/> BOLT-ON BREAKER TYPE: -
CCT	VA P BKR A B C BKR P VA	CCT
1	-	13
2	-	14
3	-	15
4	-	16
5	-	17
6	-	18
7	-	19
8	-	20
9	-	21
10	-	22
11	-	23
12	-	24

### NOTES:

- PANELBOARDS ARE SHOWN FOR SIZE AND TYPE. COMPLETE ALL CIRCUITS FOR AS-BUILT CONDITIONS.

0 23/10/06 ISSUED FOR TENDER	
NO. D / M / Y	DESCRIPTION BY
REVISIONS / ISSUE	
A. SECTION LETTER OR DETAIL NUMBER IS DRAWN	B. DRAWING WHERE SECTION OR DETAIL WAS INDICATED
- SECTION OR DETAIL SHOWN ON SAME DRAWING	
<b>KGS GROUP</b> CONSULTING ENGINEERS & PROJECT MANAGERS WINNIPEG (204) 896-1209 THUNDER BAY (807) 345-2233	
CLIENT: <b>CITY OF WINNIPEG</b> PUBLIC WORKS DEPARTMENT	
PROJECT: INSTALLATION OF EMERGENCY GENERATOR AT PAN-AM POOL - 25 POSEIDON BAY TENDER No. 663-2006	
DRAWING DESCRIPTION: ELECTRICAL SCHEDULES	
ENG. STAMP	DESIGNED BY: AP DRAWN BY: GCN
APPROVED:	CHECKED:
SCALE: AS NOTED	DATE: OCT/2006
KGS DWG. NO. 06-0107-08	REV: E6
CLIENT DWG. NO. 663-P-E06	REV: 0

Certificate of Authorization  
 KGS Group  
 No. 245 Expiry: April 30, 2007

