


MAIN FLOOR POWER PLAN
1:75

- DRAWING NOTES**
- CONTROL WIRING FROM OVERHEAD DOOR OPENER TO MOTOR.
 - CONNECT GROUND POINT IN PANEL TO BUILDING GROUND FOLLOWING PROPER METHOD.
 - PROVIDE A #10 INSULATED GROUND WIRE IN 20mm CONDUIT (UNDERGROUND) FROM WALL MOUNTED GROUND BUS TO SOUTH TRACK RAIL. MAKE THERMOWELDED CONNECTION AT RAIL. WALL MOUNTED GROUND BUS TO BE CONNECTED TO MAIN BUILDING GROUND IN ELECTRICAL ROOM.

- GENERAL NOTES**
- COORDINATE WITH OTHER TRADES SO AS TO PREVENT CONFLICTS.



<p>Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2007</p>	B.M. ELEV.	DESIGNED BY	BLM	CHECKED BY	PS	ENGINEER'S SEAL ORIGINAL SIGNED BY P. STRYK 2007/01/31 CONSULTANT DRAWING NO. WS-E0112	<p>THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION</p>	
		DRAWN BY	ERC	APPROVED BY	AHL			WATER TREATMENT PLANT BULK CHEMICAL STORAGE SODIUM HYPOCHLORITE AND CHEMICAL STORAGE BUILDING
		SCALE:	1:75	RELEASED FOR CONSTRUCTION BY:	R. SOROKOWSKI			
		NO. REVISIONS	DATE	BY	DATE			2006/10/02