


MAIN FLOOR POWER PLAN
1:75

- DRAWING NOTES**
- 1 CONTROL WIRING FROM OVERHEAD DOOR OPENER TO MOTOR.
 - 2 CONNECT GROUND POINT IN PANEL TO BUILDING GROUND AS OUTLINED IN ELECTRICAL SPECIFICATION SECTION 16160.
 - 3 PROVIDE A #10 INSULATED GROUND WIRE IN 20mm CONDUIT (UNDERGROUND) FROM WALL MOUNTED GROUND BUS TO SOUTH TRACK RAIL. MAKE THERMOWELD CONNECTION AT RAIL. WALL MOUNTED GROUND BUS TO BE CONNECTED TO MAIN BUILDING GROUND IN ELECTRICAL ROOM.

GENERAL NOTES

- 1. COORDINATE WITH OTHER TRADES SO AS TO PREVENT CONFLICTS.



APEGM
Certificate of Authorization
Earth Tech Canada Inc.
No. 730 Expiry: April 30, 2007

B.M. ELEV.					
DESIGNED BY	BLM	CHECKED BY	PS		
DRAWN BY	ERC	APPROVED BY	AHL		
SCALE:	1:75	RELEASED FOR CONSTRUCTION BY:	R. SOROKOWSKI		
NO. REVISIONS	DATE	BY	DATE	2006/10/02	2007/01/31

ENGINEER'S SEAL
ORIGINAL SIGNED BY
P. STRYK
2007/01/31
CONSULTANT DRAWING NO.
WS-E0112

THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENGINEERING DIVISION

WATER TREATMENT PLANT
BULK CHEMICAL STORAGE
SODIUM HYPOCHLORITE AND CHEMICAL STORAGE BUILDING

ELECTRICAL
MAIN FLOOR POWER PLAN

CITY FILE NUMBER
SHEET OF
CITY DRAWING NUMBER
1-0601S-A-E0112-001-03D