



**G SECTION**  
WS-H110 1:50

- DRAWING NOTES**
- ① NATURAL GAS REGULATOR.
  - ② 30mm NATURAL VENT UP TO ROOF.
  - ③ SLOPE SANITARY LINE @ 1%.
  - ④ SEE CIVIL DWG. FOR SITE SERVICES CONTINUATION.
  - ⑤ SANITARY CLEANOUT.
  - ⑥ 25mm NATURAL GAS LINE.
  - ⑦ 50mm NATURAL GAS LINE.
  - ⑧ 65mm NATURAL GAS LINE.
  - ⑨ 40mm NATURAL GAS LINE.
  - ⑩ 75mm NATURAL GAS LINE.
  - ⑪ 30mm NATURAL GAS LINE.
  - ⑫ TRAP PRIMER DCW LINE.
  - ⑬ ELECTRONIC TRAP PRIMING MANIFOLD.
  - ⑭ LOCATION OF PROPOSED ELECTRICAL DUCT BANK BY OTHERS.

- GENERAL NOTES**
1. MECHANICAL CONTRACTOR SHALL COORDINATE WITH OTHER TRADES. REPORT DISCREPANCIES TO MECHANICAL ENGINEER.
  2. MECHANICAL CONTRACTOR SHALL INSULATE ALL DOMESTIC COLD, HOT, RECERC. TEMPERED AND PROCESS HOT WATER LINES.
  3. MECHANICAL CONTRACTOR SHALL PROVIDE TRAP PRIMERS FOR ALL TRAPS.

**APECA**  
Certificate of Authorization  
Earth Tech Canada Inc.  
No. 730 Expiry: April 30, 2007

B.M. ELEV.			
00	ISSUED FOR TENDER	07/01/31	LJW
NO.	REVISIONS	DATE	BY

**CH2M HILL**  
Frederickson Cooper ARCHITECTS

**EarthTech**  
A Tech International Ltd. Company

DESIGNED BY	LJW	CHECKED BY	PVL/AMA
DRAWN BY	LJW	APPROVED BY	AHL
SCALE:	1:50	RELEASED FOR CONSTRUCTION BY:	R. SOROKOWSKI
DATE	2006/09/12	DATE	2007/01/31

ENGINEER'S SEAL  
ORIGINAL SIGNED BY  
A. M. AFTANAS  
2007/01/31  
CONSULTANT DRAWING NO.  
WS-H0205

**THE CITY OF WINNIPEG**  
WATER AND WASTE DEPARTMENT  
ENGINEERING DIVISION

WATER TREATMENT PLANT  
BULK CHEMICAL STORAGE  
SODIUM HYPOCHLORITE AND CHEMICAL STORAGE BUILDING

MECHANICAL  
SECTIONS G

CITY FILE NUMBER	
SHEET OF	
CITY DRAWING NUMBER	1-0601S-A-H0205-001-000