



- NOTE:
1. SLOPE FILL LINES TO TANKS.
 2. PIPING SHALL BE LOCATED FOR EASY ACCESS.
 3. PIPING SHALL NOT BE RUN OVER THE TOP OF TANKS UNLESS OTHERWISE SHOWN.
 4. SEE DRAWINGS WS-M0451 AND WS-M0452 FOR TANK DETAILS AND NOZZLE SCHEDULE.

<p>Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2007</p>	B.M. ELEV.	<p>Frederickson Cooper ARCHITECTS</p>	<p>A Tyco International Ltd. Company</p>	ENGINEER'S SEAL	<p>THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION</p>		
				DESIGNED BY SBW		CHECKED BY SRB	ORIGINAL SIGNED BY S.B. WILLIAMSON
				DRAWN BY JBC		APPROVED BY AHL	2007/01/31
				SCALE: 1:50		RELEASED FOR CONSTRUCTION BY: R. SOROKOWSKI	CONSULTANT DRAWING NO. WS-M0122
	00 ISSUED FOR TENDER 07/01/31 JBC	DATE 2006/03/15	DATE 2007/01/31		<p>WATER TREATMENT PLANT BULK CHEMICAL BUILDING SODIUM HYPOCHLORITE AND CHEMICAL STORAGE BUILDING</p> <p>PROCESS MECHANICAL UPPER LEVEL PLAN</p>		
	NO. REVISIONS	DATE	DATE		<p>CITY FILE NUMBER</p> <p>SHEET OF</p> <p>CITY DRAWING NUMBER 1-0601S-A-M0122-001-00D</p>		