




REV.	CABLE TAG	CABLE SPECIFICATIONS	LENGTH (m)	FROM	TO	DESCRIPTION	REMARKS
0	C-LCP-S11-C01	1-Coaxial RG-6		LCP-S11A Bulk Chemical Communication Panel	LCP-S11	Bulk Chemical Remote I/O	In Contract 792-2006.
0	C-LCP-T11-C01	1-Coaxial RG-6		LCP-T11A Clearwell Communication Panel	LCP-T11	Clearwell Remote I/O	In Contract 498-2006.
0	C-WTPAPRTR01-C01	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPAPRTR01	Router/Gateway Network Cable	In Contract 742-2005.
0	C-WTPSVES01-C01	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPSVES01	Engineering Workstation Plant Control Network Cable	In Contract 742-2005.
0	C-WTPSVES01-C02	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPSVES01	Engineering Workstation Plant Monitoring Network Cable	In Contract 742-2005.
0	C-WTPSVHIS01-C01	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPSVHIS01	Primary Historical Server Network Cable	In Contract 742-2005.
0	C-WTPSVHIS02-C01	4-Pair #24 AWG - Cat 5E		CP-H32A Backup Server Room Communication Panel	WTPSVHIS02	Standby Historical Server Network Cable	In Contract 742-2005.
0	C-WTPSVRVS01-C01	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPSVRVS01	Primary Real Time Server Plant Control Network Cable	In Contract 742-2005.
0	C-WTPSVRVS02-C01	4-Pair #24 AWG - Cat 5E		CP-H32A Backup Server Room Communication Panel	WTPSVRVS02	Standby Real Time Server Plant Control Network Cable	In Contract 742-2005.
0	C-WTPSVRVS02-C02	4-Pair #24 AWG - Cat 5E		CP-H32A Backup Server Room Communication Panel	WTPSVRVS02	Standby Real Time Server Plant Monitoring Network Cable	In Contract 742-2005.
0	C-WTPWSC11 01-C01	4-Pair #24 AWG - Cat 5E		CP-C11A Polymer Communication Panel	WTPWSC11 01	Local Operator Workstation at CP-C11	In Contract 742-2005.
0	C-WTPWSCR01-C01	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPWSCR01	Operator Workstation 01 Network Cable	In Contract 742-2005.
0	C-WTPWSCR02-C01	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPWSCR02	Operator Workstation 02 Network Cable	In Contract 742-2005.
0	C-WTPWSCR03-C01	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPWSCR03	Operator Workstation 03 Network Cable	In Contract 742-2005.
0	C-WTPWSCR04-C01	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPWSCR04	Operator Workstation 04 Network Cable	In Contract 742-2005.
0	C-WTPWSD01 01-C01	4-Pair #24 AWG - Cat 5E		CP-D01A DBPS Communication Panel	WTPWSD01 01	Interface to DBPS PLC's	In Contract 37-2006.
0	C-WTPWSF01 01-C01	4-Pair #24 AWG - Cat 5E		LCP-F01A Filters 1-4 Communication Panel	WTPWSF01 01	Local Operator Workstation at LCP-F01 Network Cable	In Contract 742-2005.

NOTES:  <p>Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2006.</p>	B.M. ELEV.				 				ENGINEER'S SEAL				THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION							
	7	FOR CONSTRUCTION	06/12/01	BT	DESIGNED BY: SWT CHECKED BY: SWT				ORIGINAL SIGNED BY: S.W. TORMEY 2006/03/29								WATER TREATMENT PLANT PLANT UTILITIES MECHANICAL AND ELECTRICAL			
	6	498-2006 ADDENDUM 6	06/10/13	BT									DRAWN BY: SWT APPROVED BY: AHL				CONSULTANT DRAWING NO. WH-A0703			
	5	498-2006 ADDENDUM 2	06/09/22	BT	SCALE: NTS				RELEASED FOR CONSTRUCTION BY: R. SOROKOWSKI											
	4	FOR CONSTRUCTION	06/07/28	BT									DATE 2006/03/29				DATE 2006/03/29			
	3	GENERAL REVISIONS	06/07/13	BT	NO. REVISIONS				DATE											
	2	742-2005 ADDENDUM 13	06/06/30	BT																
	1	742-2005 ADDENDUM 6	06/05/25	SWT																
	8	ISSUED FOR TENDER	07/01/22	BT																
	NO.	REVISIONS	DATE	BY	DATE	2006/03/29	DATE	2006/03/29												

January 12, 2007