





REV.	CABLE TAG	CABLE SPECIFICATIONS	LENGTH (m)	FROM	TO	DESCRIPTION	REMARKS
2	C-CP-O11A-C01	24-Strand 50/125/250 um Multi-mode		CP-H30A Plant Master PLC Communication Panel	CP-O11A Liquid Oxygen Communication Panel	Plant Communication	In Contract (LOX).
2	C-CP-O30A-C01	24-Strand 50/125/250 um Multi-mode		LCP-R21A Residuals Communication Panel	CP-O30A Ozone Communication Panel	Plant Communication	In Contract 742-2005.
2	C-CP-P31A-C01	24-Strand 50/125/250 um Multi-mode		CP-H32A Backup Server Room Communication Panel	CP-P31A DAF Communication Panel	Plant Communication	In Contract 742-2005.
2	C-JT-H951A-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H951A	SWGR 1A Power Meter Comm. Cable	In Contract 742-2005.
2	C-JT-H951B-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H951B	SWGR 1B Power Meter Comm. Cable	In Contract 742-2005.
2	C-JT-H952A-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H952A	MCC 1A Power Meter Comm. Cable	In Contract 742-2005.
2	C-JT-H952B-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H952B	MCC 1B Power Meter Comm. Cable	In Contract 742-2005.
2	C-JT-H953A-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H953A	MCC 2A Power Meter Comm. Cable	In Contract 742-2005.
2	C-JT-H953B-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H953B	MCC 2B Power Meter Comm. Cable	In Contract 742-2005.
2	C-JT-H954A-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H954A	MCC 3A Power Meter Comm. Cable	In Contract 742-2005.
2	C-JT-H954B-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JT-H954B	MCC 3B Power Meter Comm. Cable	In Contract 742-2005.
2	C-JT-H961A-C01	2-Strand 50/125/250 um Multi-mode		LCP-S11A Bulk Chemical Communication Panel	JT-H961A	SWGR 2A Power Meter Comm. Cable	In Contract (Bulk Chem).
2	C-JT-H961B-C01	2-Strand 50/125/250 um Multi-mode		LCP-S11A Bulk Chemical Communication Panel	JT-H961B	SWGR 2B Power Meter Comm. Cable	In Contract (Bulk Chem).
2	C-JT-H962A-C01	2-Strand 50/125/250 um Multi-mode		CP-H30A Plant Master PLC Communication Panel	JT-H962A	MCC 4A Power Meter Comm. Cable	In Contract 742-2005.
2	C-JT-H962B-C01	2-Strand 50/125/250 um Multi-mode		CP-H30A Plant Master PLC Communication Panel	JT-H962B	MCC 4B Power Meter Comm. Cable	In Contract 742-2005.
2	C-JY-H951A-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H951A	SWGR 1A Protection Relay Comm. Cable	In Contract 742-2005.
2	C-JY-H951B-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	JY-H951B	SWGR 1B Protection Relay Comm. Cable	In Contract 742-2005.

NOTES:  <p>Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2006.</p>	B.M. ELEV.			  		ENGINEER'S SEAL ORIGINAL SIGNED BY S.W. TORMEY 2006/03/29		THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION WATER TREATMENT PLANT PLANT UTILITIES MECHANICAL AND ELECTRICAL AUTOMATION / I AND C PLANT COMMUNICATION CABLES CABLE LIST	
	7	FOR CONSTRUCTION	06/12/01						
	6	498-2006 ADDENDUM 6	06/10/13	BT	SHEET 6 OF 11				
	5	498-2006 ADDENDUM 2	06/09/22	BT	CITY DRAWING NUMBER				
	4	FOR CONSTRUCTION	06/07/28	BT	1-0601H-K-A0706-001-08B				
	3	GENERAL REVISIONS	06/07/13	BT					
	2	742-2005 ADDENDUM 13	06/06/30	BT					
	1	742-2005 ADDENDUM 6	06/05/25	SWT					
	8	ISSUED FOR TENDER	07/01/22	BT					
	NO.	REVISIONS	DATE	BY	DATE	2006/03/29	DATE		

January 12, 2007