





REV.	CABLE TAG	CABLE SPECIFICATIONS	LENGTH (m)	FROM	TO	DESCRIPTION	REMARKS
2	C-LCP-F921A-C02	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	LCP-F921A Filter Backwash Pump 2 Control Panel	Filter Backwash Pump 2 Motor Protection Relay Status	In Contract 742-2005.
2	C-LCP-H10A-C01	24-Strand 50/125/250 um Multi-mode		CP-H31A Primary Server Room Communication Panel	LCP-H10A Electrical Room No. 1 Communication Panel	Plant Communication	In Contract 742-2005.
2	C-LCP-H10A-C02	24-Strand 50/125/250 um Multi-mode		CP-D01A DBPS Communication Panel	LCP-H10A Electrical Room No. 1 Communication Panel	Plant Communication	In Contract 37-2006.
2	C-LCP-I001A-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	LCP-I001A Raw Water Pump 1 Control Panel	Raw Water Pump 1 Motor Protection Relay Status	In Contract 742-2005.
2	C-LCP-I002A-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	LCP-I002A Raw Water Pump 2 Control Panel	Raw Water Pump 2 Motor Protection Relay Status	In Contract 742-2005.
2	C-LCP-I003A-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	LCP-I003A Raw Water Pump 3 Control Panel	Raw Water Pump 3 Motor Protection Relay Status	In Contract 742-2005.
2	C-LCP-I004A-C01	2-Strand 50/125/250 um Multi-mode		LCP-H10A Electrical Room No. 1 Communication Panel	LCP-I004A Raw Water Pump 4 Control Panel	Raw Water Pump 4 Motor Protection Relay Status	In Contract 742-2005.
2	C-LCP-L11A-C01	24-Strand 50/125/250 um Multi-mode		CP-D01A DBPS Communication Panel	LCP-L11A Dewatering Pump Station Control Panel	Plant Communication	In Contract (De-Watering Pumping Station)
2	C-LCP-L11A-C02	24-Strand 50/125/250 um Multi-mode		CP-D01A DBPS Communication Panel	LCP-L11A Dewatering Pump Station Control Panel	Plant Communication	In Contract (De-Watering Pumping Station)
2	C-LCP-R21A-C01	24-Strand 50/125/250 um Multi-mode		LCP-F01A Filters 1-4 Communication Panel	LCP-R21A Residuals Communication Panel	Plant Communication	In Contract 742-2005.
2	C-LCP-S11A-C01	24-Strand 50/125/250 um Multi-mode		CP-J11A Sodium Hypochlorite Communication Panel	LCP-S11A Bulk Chemical Communication Panel	Plant Communication	In Contract 792-2006.
2	C-MCC4A-C01	2-Strand 50/125/250 um Multi-mode		CP-H30A Plant Master PLC Communication Panel	MCC4A	Filter Air Scour Blower 1 Motor Protection Relay Status	In Contract 742-2005.
2	C-MCC4B-C01	2-Strand 50/125/250 um Multi-mode		CP-H30A Plant Master PLC Communication Panel	MCC4B	Filter Air Scour Blower 2 Motor Protection Relay Status	In Contract 742-2005.
2	C-PSU-O310A-C01	2-Strand 50/125/250 um Multi-mode		CP-O30A Ozone Communication Panel	PSU-O310A	Power Meter: Ozone Generator 1	In Contract 742-2005.
2	C-PSU-O320A-C01	2-Strand 50/125/250 um Multi-mode		CP-O30A Ozone Communication Panel	PSU-O320A	Power Meter: Ozone Generator 2	In Contract 742-2005.
2	C-PSU-O330A-C01	2-Strand 50/125/250 um Multi-mode		CP-O30A Ozone Communication Panel	PSU-O330A	Power Meter: Ozone Generator 3	In Contract 742-2005.
2	TBA Gen-1	2-Strand 50/125/250 um Multi-mode		CP-H11A Generator Communication Panel	TBA Gen-1	Power Meter: Generator 1 Comm. Cable	In Contract 498-2006.

NOTES:   <p>Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2006.</p>	B.M. ELEV.				  				ENGINEER'S SEAL		<b>THE CITY OF WINNIPEG</b> <b>WATER AND WASTE DEPARTMENT</b> <b>ENGINEERING DIVISION</b>			
	7	FOR CONSTRUCTION	06/12/01	BT	DESIGNED BY		SWT	CHECKED BY		SWT				
	6	498-2006 ADDENDUM 6	06/10/13	BT	DRAWN BY		SWT	APPROVED BY		AHL	PLANT UTILITIES		SHEET 8 OF 11	
	5	498-2006 ADDENDUM 2	06/09/22	BT	SCALE:		NTS	RELEASED FOR CONSTRUCTION BY:		R. SOROKOWSKI	AUTOMATION / I AND C		CITY DRAWING NUMBER	
	4	FOR CONSTRUCTION	06/07/28	BT	DATE		2006/03/29	DATE		2006/03/29	PLANT COMMUNICATION CABLES		1-0601H-K-A0708-001-08B	
	3	GENERAL REVISIONS	06/07/13	BT	CONSULTANT DRAWING NO.		WH-A0708							
	2	742-2005 ADDENDUM 13	06/06/30	BT										
	1	742-2005 ADDENDUM 6	06/05/25	SWT										
	8	ISSUED FOR TENDER	07/01/22	BT										
	NO.	REVISIONS	DATE	BY										