

MISCELLANEOUS EQUIPMENT SYMBOLS

	ORIFICE PLATE		FILTER		FLOW STRAIGHTENING VANES
	FLANGE		MAGNETIC FLOW METER ELEMENT		AIR FILTER (HVAC)
	PIPE REDUCER		EXPANSION JOINT		MIXER
	PUMP		TRAP		PUMP, DIAPHRAGM
	FAN/BLOWER		MIX TEE		PUMP, DIAPHRAGM OPERATED
	PROPELLER OR TURBINE METER		DUPLEX STRAINER		PUMP, GEAR
	STRAINER		MIXER, IN-LINE STATIC		PULSATION DAMPER
	DRAIN		FLOW NOZZLE		AIR SEPARATOR
	UNION		FLOAT		MIXER
	TEMPERATURE ELEMENT WITH THERMOWELL		SINGLE PORT PITOT TUBE		SITE GLASS
	SCREWED CAP		AVERAGING PITOT TUBE		COMPRESSOR ROTARY SCREEN
	FIRE HYDRANT		SLUICE GATE		FLEXIBLE HOSE
	HOSE STATION		SLIDE GATE		IN-LINE FLOW METER
	ANNUNCIATOR HORN		VARIABLE AREA FLOW INDICATOR (ROTAMETER)		INJECTOR
	GROUND		VORTEX FLOW METER		EQUIPMENT MOTOR
	CORIOLIS MASS FLOWMETER		GENERATOR		WEIR
	FLOAT LEVEL ELEMENT		HEAT EXCHANGER		PUMP, ROTARY LOBE
	FLOW ELEMENT INTEGRAL WITH TRANSMITTER (MASS FLOW, ETC)		FLAME CHECK		PUMP, METERING
	SONIC FLOWMETER (DOPPLER OR TRANSIT TIME)		CALIBRATION CHAMBER		PUMP, PROGRESSIVE CAVITY
	EJECTOR		EMERGENCY EYE WASH AND SHOWER		BAR SCREEN, MECHANICAL
	FILTER		BOILER		DIFFUSER HEADER
	SILENCER		RECEIVER OR PRESSURE VESSEL		ENGINE
	GRINDER		TANK, DOUBLE WALLED		
	STOP LOG		TANK		
	LEVEL CONTROL GATE		LIQUID SEPARATOR		
			PUMP, SUBMERSIBLE		
			PUMP, VERTICAL		

VALVES

VALVE BODIES			STOP CHECK
	NORMALLY OPEN GATE VALVE		SPRING OPERATED CHECK
	NORMALLY CLOSED GATE VALVE		AIR ASSISTED CHECK
	NORMALLY OPEN GLOBE VALVE		COCK VALVE
	NORMALLY CLOSED GLOBE VALVE		DUCKBILL VALVE
	NORMALLY OPEN BALL VALVE		DIAPHRAGM VALVE
	NORMALLY CLOSED BALL VALVE		FLAP VALVE
	BUTTERFLY		FLOAT VALVE
	NEEDLE		MUD VALVE
	CHECK		QUICK CONNECT AIR HOSE COUPLING
	PLUG		TELESCOPIC VALVE
	KNIFE		BLAST GATE
	PINCH		SPECTACLE BLIND (OPEN)
	BALL CHECK		SPECTACLE BLIND (CLOSED)
	DOUBLE LEAF CHECK		UNCLASSIFIED WRITE TYPE OF BODY ADJACENT TO SYMBOL
	ANGLE		AIR AND VACUUM RELIEF VALVE
	ANGLE AND GATE PRESSURE RELIEF VALVE		
	GATE PRESSURE RELIEF VALVE		
	IN-LINE SAFETY		

CONTROL VALVES

	ROTARY BALL VALVE		BACKPRESSURE REGULATOR, SELF-CONTAINED
	CYLINDER-ACTUATED SINGLE-ACTING		BACKPRESSURE REGULATOR, WITH EXTERNAL PRESSURE TAP
	CYLINDER-ACTUATED DOUBLE-ACTING		CONE VALVE
	PRESSURE-REDUCING REGULATOR, SELF-CONTAINED		THREE-WAY VALVE
	PRESSURE-REDUCING REGULATOR, WITH EXTERNAL PRESSURE TAP		FOUR-WAY VALVE
	VALVE WITH BLEED		AIR RELEASE VALVE

VALVE ACTUATORS/OPERATORS

	HAND OPERATOR		DIAPHRAGM OPERATOR WITH POSITIONER
	DIAPHRAGM OPERATOR		DIAPHRAGM OPERATOR WITH POSITIONER FAIL OPEN
	SOLENOID OPERATOR		DIAPHRAGM OPERATOR WITH POSITIONER FAIL CLOSE
	MOTOR OPERATOR		
	PNEUMATIC CYLINDER		

MISCELLANEOUS

LINE SYMBOLS -- PROCESS & INSTRUMENTATION DIAGRAMS

	MAIN PROCESS LINES
	SECONDARY PROCESS LINES
	ALL OTHER MECHANICAL LINES
	ELECTRIC SIGNAL
	ELECTRICAL BINARY (ON/OFF) SIGNAL
	PNEUMATIC SIGNAL
	PNEUMATIC BINARY SIGNAL
	CAPILLARY TUBING
	HYDRAULIC SIGNAL
	INTERNAL SYSTEM LINK (SOFTWARE OR DATA LINK)
	ELECTROMAGNETIC or SONIC SIGNAL (GUIDED AND NOT GUIDED)
	TELEMETERED SIGNAL
	SUPPLY CONTRACTOR PACKAGE
	VENDOR PACKAGE
	LOCAL CONTROL PANEL/MCC
	INSTRUMENT SUPPLY OR CONNECTION TO PROCESS DESIGNATED AS FOLLOWS:
	AS = AIR SUPPLY
	ES = ELECTRICAL SUPPLY
	GS = GAS SUPPLY
	HS = HYDRAULIC SUPPLY
	NS = NITROGEN SUPPLY
	SS = STEAM SUPPLY
	WS = WATER SUPPLY

PID STANDARDS

- DRAWINGS UTILIZE CITY OF WINNIPEG STANDARDS FOR BORDER AND TITLE BLOCK. ALL DRAWINGS ARE PRODUCED ON AUTOCAD (LATEST REV., R2000 OR LATER).
- ALL UNITS ARE IN METRIC, EXCEPT AS NOTED OTHERWISE. ALL DIMENSIONS SHOWN ARE IN MILLIMETERS (mm).
- DRAWING CONTENT GENERALLY CONFORMS TO ANSI/ISA STANDARDS S5.1 & S5.3.
- PID'S INDICATE MAJOR PROCESS PIPING AND EQUIPMENT AND ASSOCIATED LOCAL INSTRUMENTATION, DCS AND OTHER PROCESS I/O.
- EQUIPMENT INCLUDING VESSELS, DRUMS, EXCHANGERS, HEATERS, PUMPS, COMPRESSORS, ETC. ARE ARRANGED IN SEQUENCE WITH PRINCIPLE FUNCTIONS AND FLOWS.
- ALL MAJOR EQUIPMENT INCLUDING PUMPS, COMPRESSORS, TANKS, ETC. ARE LABELLED AS TO FUNCTION WITH DESIGN SIZES AND RATINGS.
- ALL PROCESS LINES ARE LABELLED ACCORDING TO FUNCTION AND SIZE UTILIZING SYSTEM CODES DEFINED HEREIN.
- EACH SYSTEM INTERCONNECTION POINT BETWEEN DRAWINGS IS LABELLED WITH A SOURCE DRAWING NUMBER OR DESTINATION DRAWING NUMBER. ARROWS ON PROCESS PIPING INDICATE DIRECTION OF FLOW BETWEEN DRAWINGS.

MISCELLANEOUS SYMBOLS

	WATER LEVEL SYMBOL
	ELECTRICAL HEAT TRACING
	FLOW DIRECTION ARROWS
	WALL
	GRADE

 Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2006	B.M. ELEV.	 Frederickson Cooper ARCHITECTS	 A Tech International Ltd. Company	ENGINEER'S SEAL ORIGINAL SIGNED BY S.R. BILEVICIUS 2006/03/29	 THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION																									
	<table border="1"> <tr> <td>DESIGNED BY</td> <td>SWT</td> <td>CHECKED BY</td> <td>SWT</td> </tr> <tr> <td>DRAWN BY</td> <td>LAE</td> <td>APPROVED BY</td> <td>AHL</td> </tr> <tr> <td>SCALE:</td> <td>NONE</td> <td>RELEASED FOR CONSTRUCTION BY:</td> <td>R. SOROKOWSKI</td> </tr> <tr> <td>NO.</td> <td>REVISIONS</td> <td>DATE</td> <td>DATE</td> </tr> <tr> <td>01</td> <td>ISSUED FOR CONSTRUCTION</td> <td>06/07/28</td> <td>JBC</td> </tr> <tr> <td>00</td> <td>ISSUED FOR TENDER</td> <td>06/03/29</td> <td>LAE</td> </tr> <tr> <td>00</td> <td>ISSUED FOR TENDER</td> <td>06/03/29</td> <td>LAE</td> </tr> </table>	DESIGNED BY	SWT	CHECKED BY	SWT	DRAWN BY	LAE	APPROVED BY	AHL	SCALE:	NONE	RELEASED FOR CONSTRUCTION BY:	R. SOROKOWSKI	NO.	REVISIONS	DATE	DATE	01	ISSUED FOR CONSTRUCTION	06/07/28	JBC	00	ISSUED FOR TENDER	06/03/29	LAE	00	ISSUED FOR TENDER	06/03/29	LAE	CONSULTANT DRAWING NO. WM-P0002
DESIGNED BY	SWT	CHECKED BY	SWT																											
DRAWN BY	LAE	APPROVED BY	AHL																											
SCALE:	NONE	RELEASED FOR CONSTRUCTION BY:	R. SOROKOWSKI																											
NO.	REVISIONS	DATE	DATE																											
01	ISSUED FOR CONSTRUCTION	06/07/28	JBC																											
00	ISSUED FOR TENDER	06/03/29	LAE																											
00	ISSUED FOR TENDER	06/03/29	LAE																											