



*NOTE 1
TIDEFLEX DUCKBILL CHECK VALVE

H₂SO₄ BULK TANKS
 QTY: 2
 CAPACITY: 94m³ EACH
 DIMENSIONS: 4.0m ϕ x 8.5m H
 MATERIAL: 316L STAINLESS STEEL

<p>Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2007</p>	<p>Frederickson Cooper ARCHITECTS</p>		<p>A Type International Ltd. Company</p>		ENGINEER'S SEAL ORIGINAL SIGNED BY S.B. WILLIAMSON 2007/01/31		<p>THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION</p>	
	DESIGNED BY: SBW CHECKED BY: NT		DRAWN BY: JBC APPROVED BY: AHL		CONSULTANT DRAWING NO. WS-P0002		WATER TREATMENT PLANT BULK CHEMICAL STORAGE SODIUM HYPOCHLORITE AND CHEMICAL STORAGE BUILDING	
	SCALE: NONE RELEASED FOR CONSTRUCTION BY: R. SOROKOWSKI		DATE: 2005/09/25 DATE: 2007/01/31		PROCESS SULPHURIC ACID FEED SYSTEM 1 OF 2 PROCESS AND INSTRUMENTATION DIAGRAM		CITY FILE NUMBER SHEET OF CITY DRAWING NUMBER 1-0601S-G-P0002-001-03D	
	NO. REVISIONS DATE BY		03 ISSUED FOR CONSTRUCTION 07/05/25 LAE 02 792-2006 ADDENDUM 9 07/04/23 LAE 01 792-2006 ADDENDUM 4 07/04/05 JBC 00 ISSUED FOR TENDER 07/01/31 JBC					