



*NOTE 1
TIDEFLEX DUCKBILL CHECK VALVE

FeCl₃ BULK TANKS
 QTY: 4
 CAPACITY: 94m³ EACH
 DIMENSIONS: 4.0m ϕ x 8.5m H
 MATERIAL: FIBERGLASS

 Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2007	B.M. ELEV.	 Frederickson Cooper ARCHITECTS	 A Tyco International Ltd. Company	ENGINEER'S SEAL	 THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION		
				DESIGNED BY: SBW		CHECKED BY: NT	ORIGINAL SIGNED BY: S.B. WILLIAMSON
				DRAWN BY: JBC		APPROVED BY: AHL	2007/01/31
				SCALE: NONE		RELEASED FOR CONSTRUCTION BY: R. SOROKOWSKI	CONSULTANT DRAWING NO. WS-P0005
	NO. REVISIONS	DATE	DATE	2005/08/15	2007/01/31	WATER TREATMENT PLANT BULK CHEMICAL STORAGE SODIUM HYPOCHLORITE AND CHEMICAL STORAGE BUILDING	CITY FILE NUMBER
						PROCESS FERRIC CHLORIDE FEED SYSTEM 1 OF 3 PROCESS AND INSTRUMENTATION DIAGRAM	SHEET OF
							CITY DRAWING NUMBER
							1-0601S-G-P0005-001-04D