



## 286-2007 ADDENDUM 3

### VALOUR COMMUNITY CENTRE GYMNASIUM ADDITION AND RENOVATIONS

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY**

ISSUED: JANUARY 30, 2008  
BY: Bruce Pauls – Harold Funk Architect Inc.  
TELEPHONE NO. (204) 943-5087

**THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS**

Template Version: A20070419

---

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

---

#### **PART E – SPECIFICATIONS**

##### Section 03 30 00

Replace: Replace this section in it's entirety with section 03 30 00 R1 provided as part of this addendum.

##### Section 26 09 10

Revise 1.2 to read: All thermostats in exposed areas **except gymnasium** shall be complete with lockable Lexcan vandal resistant guards. Thermostats shall be 7-day programmable with night set back functions and 3-hour override function.

#### **DRAWINGS**

Replace: 286-2007\_Drawing\_M3\_R0 with 286-2007 \_Addendum\_ Drawing M3\_R1

Replace: 286-2007\_Drawing\_M4\_R0 with 286-2007 \_Addendum\_ Drawing M4\_R1