



NO.	CONSTRUCTION NOTES
1	ADJUST TRIP SETTING ON EXISTING BREAKER TO 175A.

- NOTES:**
- THIS DRAWING WAS CREATED BASED UPON EXISTING DOCUMENTATION, AND A DETAILED SITE VERIFICATION WAS NOT PERFORMED AT THE TIME OF DRAWING CREATION. THE CITY OF WINNIPEG IS RESPONSIBLE FOR VERIFICATION OF THE EXISTING INSTALLATION REPRESENTED ON THIS DRAWING.
 - ALL METERING AND MOTOR CONTROL FUNCTIONS ARE NOT SHOWN ON THIS DRAWING.

1-0101G-F-E0001	GRIT 4160V DISTRIBUTION SINGLE LINE DIAGRAM
1-0101A-F-E0001	4160V ELECTRICAL DISTRIBUTION SWITCHING DIAGRAM
DRAWING NUMBER	REFERENCE DRAWINGS

B.M. ELEV.	FIELD BOOK #:	SNC • LAVALIN Engineers & Constructors		SNC • LAVALIN 148 Nature Park Way Winnipeg, Manitoba Canada R3P 0X7	
POSTED TO LBIS		DESIGNED BY	EXISTING	CHECKED BY	CJR
		DRAWN BY	DEB	APPROVED BY	C. REIMER
		HOR. SCALE	NTS	RELEASED FOR CONSTRUCTION	
00	ISSUED FOR TENDER	2007/06/22	YOM	DATE	2006/07/07
NO.	REVISIONS	DATE	BY	FILENAME:	1-0101M-F-E0001-001-000.dwg

ENGINEER'S SEAL
PRELIMINARY
 NOT TO BE USED FOR CONSTRUCTION

THE CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT

NORTH END WATER POLLUTION CONTROL CENTRE
 MAIN BUILDING
 SINGLE LINE DIAGRAM
 ELECTRICAL DISTRIBUTION

CITY DRAWING NUMBER	SHEET	REV.	SIZE
1-0101M-F-E0001	001	00	D