


PLAN LEVEL 300 1 M0009



- NOTE:**
1. ALL NEW STEEL WORK, BRACKETS, ETC., TO BE GALVANIZED UNLESS OTHERWISE NOTED.
 2. APPLY 304 SS, 25mm OPENING WIRE MESH TO ALL DUCTS OPENINGS IN WET WELL AREA.
 3. ALL WET WELL DUCTING TO BE SS.

APEGM
 Certificate of Authorization
 UMA Engineering Ltd. (MB)
 No. 256 Date: 07/12/14

RS	ALS	CC	CC	BP
DRN	CHK	DES	ENG	IDR
UMA REVIEW				

B.M. ELEV.	FIELD BOOK #:	UMA AECOM	
POSTED TO LBIS		DESIGNED BY CAC	CHECKED BY -----
		DRAWN BY RJP	APPROVED BY -
D ISSUED FOR BID	07/12/14	RS	
C ISSUED FOR 100% REVIEW	07/11/09	RS	
B ISSUED FOR ZONING	07/08/21	ALS	
A ISSUED FOR 80% REVIEW	07/06/18	RJP	
NO. REVISIONS	DATE	BY	FILENAME: D265-202-02_01-M-0009_RX.dwg

ENGINEER'S SEAL	
ISSUE / REVISION	RELEASED FOR CONSTRUCTION
ISSUED FOR BID	07/12/14
ISSUED FOR 100% REVIEW	07/11/09
ISSUED FOR ZONING	07/08/21
ISSUED FOR 80% REVIEW	07/06/18

ISSUE / REVISION ISSUED FOR BID WAS SEALED BY CLAUDE COURCHAINE AND DATED 07/12/14

THE CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT

PERIMETER ROAD PUMPING STATION UPGRADES
 Contract B - Building Upgrades

Mechanical - New Construction
 LEVEL 300 FLOOR PLAN

CITY DRAWING NUMBER: 1-0111L-M0009 SHEET REV. SIZE: 001 D D