

Glycol Heating Coil Schedule															
Tag	Service	Manufacturer	Model	Airflow (LPS)	EAT (C)	LAT (C)	Glycol Data			Flow (LPM)	Capacity (kW)	Coil Size (mm)		SP Loss (Pa)	Comments
							EWT (C)	LWT (C)	Loss (m)			Width	Height		
HC-6	AH-6	McQuay	5WH1002C	1,275	-34.4	23.9	82.2	71.1	1.9	9.2	90.9	914	533	88	50% ethylene glycol
HC-7	AH-7	McQuay	5WH0902C	1,420	-34.4	22.3	82.2	71.1	2.3	10.5	98.2	1,067	533	75	50% ethylene glycol
HC-8	AH-8	McQuay	5WH1102C	710	-34.4	22.3	82.2	71.7	0.7	5.3	48.9	559	457	100	50% ethylene glycol