



UMA FILE NAME: F963-001-01-E-002-RX.dwg
 DATE: 2007.02.21
 DESCRIPTION: Site Plan - Demolition
 PROJECT No: F963-001-01
 ADDRESS: 999 Sargent St. Winnipeg, Manitoba
 PLOT: 07/08/22 2:42:02 PM



SITE PLAN



GENERAL ELECTRICAL NOTES:

- G0. THESE NOTES APPLY TO ALL DRAWINGS.
- G1. REFER TO FRONT END SPECIFICATION FOR TIME AND DATE RESTRICTIONS RELATED TO WORK IN EXISTING BUILDING.
- G2. EXISTING BUILDING WILL REMAIN IN OPERATION DURING ADDITION EXCEPT DURING SPECIFIED SHUT DOWN PERIODS.
- G3. REFER TO SPECIFICATION 16133 FOR RACEWAYS IN EXISTING BUILDING.
- G4. ALL NEW ELECTRICAL EQUIPMENT TO BE SPRINKLER PROOF.
- G5. SPRINKLER PROOFING OF EXISTING ELECTRICAL EQUIPMENT DURING THE RENOVATION THE EXISTING (AND NEW) BUILDING WILL BE SPRINKLERED. THE FOLLOWING EXISTING ELECTRICAL EQUIPMENT REQUIRE RETROFITTING WITH SPRINKLER PROTECTION:
 - MAIN, SUB DISTRIBUTIONS AND PANELBOARDS
 - MOTOR CONTROL CENTRES
 - SPLITTERS
 - TRANSFORMERS
 - BUS DUCT (UTILITY VAULT TO MAIN DISTRIBUTION CDP-100 (VAULT IS NOT SPRINKLERED))
 - STARTERS AND DISCONNECTS
 - CONDUITS PENETRATING TOPS OF EQUIPMENT WHERE WATER COULD ENTER
 - CONTROL PANELS
- THE FOLLOWING DO NOT REQUIRE SPRINKLER PROTECTION:
 - RECESSED PANELBOARDS
 - EQUIPMENT IN ELECTRICAL VAULT
- SPRINKLER HOODS ARE TO BE SUPPLIED BY AN ELECTRICAL EQUIPMENT MANUFACTURER. STANDARD OF ACCEPTANCE: J.R. STEVENSON OR DISTRIBUTION EQUIPMENT SUPPLIER.
- G6. REFER TO ARCHITECTURAL DRAWINGS FOR ROOM NAMES, ROOM NUMBERS AND DOOR NUMBER. REFER TO REFLECTED CEILING PLANS FOR LUMINAIRE AND SPEAKER PLACEMENT. REFER TO MILLWORK DETAILS FOR CONNECTION OF MILLWORK SUPPLIED LIGHTING.

NOTE

1. ALL PARKING LOT ELECTRICAL PART OF SEPARATE CONTRACT, (REFER TO SPECIFICATION).
2. ELECTRICAL CONTRACTOR TO PROVIDE BREAKOUT PRICE FOR SECURITY MANAGEMENT SYSTEM (PEGASYS CARD ACCESS) AFTER AWARD FOR INTERNET ACCOUNTING PURPOSES.
3. CONFIRM WATTAGE OF EXISTING LAWN BUILDING LIGHTS AND CAPACITY OF NEW CIRCUIT TO ACCOMMODATE. OWNER HAS ADVISED THAT ALL 24 LAWN BUILDING LUMINAIRES HAVE 400W M.H.

UMA | AECOM

© 2007 UMA ENGINEERING LTD. ALL RIGHTS RESERVED.

APECM

Certificate of Authorization
 UMA Engineering Ltd. (MB)
 No. 256 Date: Aug 21, 2007

DRN	CHK	DES	ENG	IDR

UMA | AECOM REVIEW

NO.	REVISION/DESCRIPTION	BY	DATE
1	ISSUED FOR ADDENDUM #2	QL	07/08/21
0	ISSUED FOR TENDER	QL	07/07/23

DRAWN BY	QL	CHECKED BY	USER APPROVAL	APPROVED
DATE	2007.02.21			

CITY OF WINNIPEG
 PLANNING, PROPERTY &
 DEVELOPMENT DEPARTMENT
 CIVIC ACCOMMODATIONS DIVISION
 300 - 65 GARRY ST. R3C 4K4

PROJECT
**Construction of Cindy Klassen
 Recreation Complex Facility
 Enhancement Project**
 999 Sargent St. Winnipeg, Manitoba

SHEET TITLE	PROJECT NO.	SHEET NO.
Electrical Site Plan	2005-059	E0.2

DRAWING SHEET SIZE: A1 (841mm x 594mm) PLOT 1:1