

Exhaust Fan Schedule								
Tag	Service	Manufacturer	Model	Airflow (LPS)	TSP (Pa)	Motor (W)	Voltage	Accessories
F-6	Penthouse Mech Room	Greenheck	CSP-A1410	660	125	822	600 / 3	Vibration isolators
F-7	Elevator Machine Room	Greenheck	CSP-A190	75	188	100	120 / 1	Vibration isolators