


PLAN
 1
 M3.2
 0 2000 4000 6000 mm SCALE 1:200
 MAIN FLOOR FIRE PROTECTION



GENERAL NOTES:

THE SPRINKLER SYSTEM SHALL BE DESIGNED AND INSTALLED TO MEET THE REQUIREMENTS OF NFPA-13, STANDARD FOR THE INSTALLATION OF SPRINKLER SYSTEMS, 2002 EDITION.

ALL SPACES AND ROOMS SHALL BE DESIGNED AS LIGHT HAZARD IN ACCORDANCE WITH NFPA-13, EXCEPT AS INDICATED BELOW AND AS NOTED OTHERWISE WHICH SHALL BE DESIGNED TO ORDINARY HAZARD GROUP 1 IN ACCORDANCE WITH NFPA-13 OR AS INDICATED.

COORDINATE SPRINKLER HEAD LOCATIONS WITH ARCHITECTURAL DRAWINGS. COORDINATE SPRINKLER HEAD LOCATIONS WITH NEW LIGHTING, EXISTING LIGHTING, BULKHEADS, DIFFUSERS AND GRILLES IN NEW AND EXISTING CEILINGS.

ALL SPRINKLER LINE PENETRATIONS THROUGH ALL WALLS ARE TO BE FIRESTOPPED.

SPRINKLER HEAD TEMPERATURES GIVEN ARE TO BE USED AS ONLY A GUIDE. HIGHER TEMPERATURE HEADS ARE REQUIRED NEAR HEAT SOURCES.

PROVIDE HEADS GUARDS ON ALL EXPOSED HEADS.

ORDINARY HAZARD GROUP 1:

RECORDING U:03
 P.A. ROOM U:05
 STORAGE
 NETWORK ROOM

UMA | AECOM

© 2007 UMA ENGINEERING LTD. ALL RIGHTS RESERVED.

APECM
 Certificate of Authorization
 UMA Engineering Ltd. (MB)
 No. 256 Date: 07/07/23

DRN CHK DES ENG IDR
 UMA | AECOM REVIEW

0	ISSUED FOR TENDER	RJP	07/07/23
NO.	REVISION/DESCRIPTION	BY	DATE

SEALS

PROVINCE OF MANITOBA
 July 20, 2007
 B.M.
 PETERSON
 REGISTERED PROFESSIONAL ENGINEER

DRAWN BY RJP CHECKED BY APPROVED
 DATE 2007.07.17 USER APPROVAL

CITY OF WINNIPEG
 PLANNING, PROPERTY & DEVELOPMENT DEPARTMENT
 CIVIC ACCOMMODATIONS DIVISION
 300 - 65 GARRY ST. R3C 4K4

PROJECT
 Construction of Cindy Klassen
 Recreation Complex Facility
 Enhancement Project
 989 Sargent St. Winnipeg, Manitoba

SHEET TITLE
 Mechanical
 Main Floor And Library Addition
 Fire Protection

SCALE 1:200 PROJECT NO. 2005-059 SHEET NO. M3.2

DRAWING SHEET SIZE: A1 (841mm x 594mm) PLOT 1:1