

INSTRUMENT INDEX

RECORD NO.	REV. No.	TAG NAME	DESCRIPTION		SPEC.	P&ID	INSTRUMENT	INSTALLATION	LOCATION
			INSTRUMENT TYPE	SERVICE	DATA SHEET	DRAWING	LOOP DIA.	DETAIL	DWG.
5	3	FI-T104A	Sample Flow Indicator	Clearwell Chloramination Analyzer Sample Flow		WT-P001			
6	3	AE-T104A	Analyzer Element	Clearwell Total Chlorine, Total Ammonia, Free Ammonia and Monochloramine	I180	WT-P001			WT-E0112
7	3	AT-T104A	Analyzer/Transmitter	Clearwell Total Chlorine, Total Ammonia, Free Ammonia and Monochloramine	I180	WT-P001			WT-E0112
8	3	FI-T105A	Sample Flow Indicator	Clearwell Free Chlorine Analyzer Sample Flow		WT-P001			
9	3	AE-T105A	Analyzer Element	Clearwell Free Chlorine	I170	WT-P001			WT-E0112
10	3	AT-T105A	Free Chlorine Analyzer/Transmitter	Clearwell Free Chlorine	I170	WT-P001			WT-E0112
12	4	AE-T106A	Analyzer Element	Clearwell pH	I170	WT-P001			WT-E0112
13	4	AT-T106A	pH Analyzer/Transmitter	Clearwell pH	I170	WT-P001			WT-E0112
14	3	FI-T107A	Sample Flow Indicator	Clearwell Turbidity Analyzer Sample Flow		WT-P001			
15	3	AE-T107A	Analyzer Element	Clearwell Turbidity	I162	WT-P001			WT-E0112
16	3	AT-T107A	Turbidity Analyzer/Transmitter	Clearwell Turbidity	I162	WT-P001			WT-E0112
21	3	FI-T204A	Sample Flow Indicator	Clearwell Chloramination Analyzer Sample Flow		WT-P001			
22	3	AE-T204A	Analyzer Element	Clearwell Total Chlorine, Total Ammonia, Free Ammonia and Monochloramine	I180	WT-P001			WT-E0112
23	3	AT-T204A	Analyzer/Transmitter	Clearwell Total Chlorine, Total Ammonia, Free Ammonia and Monochloramine	I180	WT-P001			WT-E0112
24	3	FI-T205A	Sample Flow Indicator	Clearwell Free Chlorine Analyzer Sample Flow		WT-P001			
25	3	AE-T205A	Analyzer Element	Clearwell Free Chlorine	I170	WT-P001			WT-E0112
26	3	AT-T205A	Free Chlorine Analyzer/Transmitter	Clearwell Free Chlorine	I170	WT-P001			WT-E0112
28	4	AE-T206A	Analyzer Element	Clearwell pH	I170	WT-P001			WT-E0112
29	4	AT-T206A	pH Analyzer/Transmitter	Clearwell pH	I170	WT-P001			WT-E0112
30	3	FI-T207A	Sample Flow Indicator	Clearwell Turbidity Analyzer Sample Flow		WT-P001			
31	5	AE-T207A	Analyzer Element	Clearwell Turbidity	I162	WT-P001			WT-E0112
32	5	AT-T207A	Turbidity Analyzer/Transmitter	Clearwell Turbidity	I162	WT-P001			WT-E0112
33	1	SP-T103A	Sample Pump	Clearwell Sample Pump #1 SP-T103A		WT-P001			WT-E0112
34	1	SP-T203A	Sample Pump	Clearwell Sample Pump #2 SP-T203A		WT-P001			WT-E0112
35	5	AT-D911A	Analyzer/Transmitter	DBPS Branch 2 Total Chlorine, Total Ammonia, Free Ammonia and Monochloramine	I180	WD-P0006			
36	5	AE-D911A	Analyzer Element	DBPS Branch 2 Total Chlorine, Total Ammonia, Free Ammonia and Monochloramine	I180	WD-P0006			
37		FI-D911A	Sample Flow Indicator	DBPS Branch 2 Chloramination Analyzer Sample Flow		WD-P0006			
38		FI-D912A	Sample Flow Indicator	DBPS Branch 2 Free Chlorine Analyzer Sample Flow		WD-P0006			
39	5	AT-D912A	Free Chlorine Analyzer/Transmitter	DBPS Branch 2 Free Chlorine	I170	WD-P0006			
40	5	AE-D912A	Analyzer Element	DBPS Branch 2 Free Chlorine	I170	WD-P0006			
41	5	AT-D901A	Analyzer/Transmitter	DBPS Branch 1 Total Chlorine, Total Ammonia, Free Ammonia and Monochloramine	I180	WD-P0013			
42	5	AE-D901A	Analyzer Element	DBPS Branch 1 Total Chlorine, Total Ammonia, Free Ammonia and Monochloramine	I180	WD-P0013			
43		FI-D901A	Sample Flow Indicator	DBPS Branch 1 Chloramination Analyzer Sample Flow		WD-P0013			
44		FI-D902A	Sample Flow Indicator	DBPS Branch 1 Free Chlorine Analyzer Sample Flow		WD-P0013			
45	5	AT-D902A	Free Chlorine Analyzer/Transmitter	DBPS Branch 1 Free Chlorine	I170	WD-P0013			
46	5	AE-D902A	Analyzer Element	DBPS Branch 1 Free Chlorine	I170	WD-P0013			