



## **ADDENDUM 2 BID OPPORTUNITY 803-2007**

### **WINNIPEG WATER TREATMENT PROGRAM – SUPPLY AND INSTALLATION OF FIRESTOPPING**

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: February 22, 2008

BY: Gord Smith, P. Eng.

TELEPHONE NO. (204) 986-4249

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20050506

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.**

---

#### **PART E – SPECIFICATIONS**

##### **Section 01300**

Add: 1.1.3

Certified and Listed Firestop Systems in accordance with the documents shall be provided. Where a Certified and Listed Firestop System is not available for a specific location/application, a detail bearing the stamp and seal of the Fire Protection Engineer registered in the Province of Manitoba shall be submitted in accordance with Section 01300 and Section 07840.