



915-2007 ADDENDUM 2

Supply and Installation of Illuminated Transit Signage and Transit Passenger Shelters –Phase 2

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: January 16, 2007
BY: Jackie Wilkie
TELEPHONE NO. (204) 956-0396

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise: E12.14 to read: Door closures shall be LCN 4040 Super Smoothie Series (certified under ANSI Standard A156.4, grade one, UL and ULC listed) with all weather hydraulic fluid tested from -130 F to 130 F manufactured by LCN Closures PO Box 100 121 W. Railroad Ave. Princeton, Illinois 61356-0100. Contact Noble Locksmith Limited at (204) 942-3703 for more information.