



# ADDENDUM 7 BID OPPORTUNITY NO. 94-2007

## CITY OF WINNIPEG WATER TREATMENT PROGRAM CONSTRUCTION OF SITE UTILITIES

### URGENT

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: June 20, 2007  
BY: Lawrence Recksiedler, C.E.T.  
TELEPHONE NO. (204) 986-4246

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20050301

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.**

---

### PART E – SPECIFICATIONS

#### Section 16610

- Revise: 2.1.2.2 to read: UPS Unit
- Add: 2.1.2.2.1 The UPS shall be located at the Dewatering Pumping Station, which shall be a rack mounted unit (a Liebert GXT or similar) installed in the network control panel LCP-L11A. The UPS shall be sized to provide power to the control panels and instrumentation.
- Add: 2.1.2.2.2 The network panel and UPS shall be fed from Panel PP-L12; the UPS shall then supply power to the equipment mounted in the communications panel LCP-L11A, the pumping station instrumentation and the control equipment mounted in the pump control panel LCP-L11.
- Delete: 2.5

#### Drawings

Clarification: With respect to Drawing WL-E0112, add one 15 amp circuit to Panel PP-L12 for service to the UPS unit.

#### Drawings

The following Drawings have been revised and are included in this Addendum:

<u>Consultant Drawing No.</u>	<u>City Drawing No.</u>	<u>Drawing Name/Title</u>
WL-C0405	1-0601L-A-C0405-001-03D	CIVIL – DEWATERING PUMP STATION
WL-P0002	1-0601L-G-P0002-001-03D	PROCESS – DEWATERING PUMP STATION – PROCESS AND INSTRUMENTATION DIAGRAM