

KEY NOTES:

1) INSTALL NEW HIGH DENSITY SCRUBBER (HDS) ON FLOOR.

2 INSTALL NEW 4 TON ROOFTOP AIR CONDITIONING SYSTEM AS SHOWN. PROVIDE ROOF CURB AND PENETRATIONS. ALL ROOFING MODIFICATIONS SHALL BE DONE BY A QUALIFIED ROOFING CONTRACTOR.

INSTALL NEW DUCTWORK AND SEAL AIR TIGHT AS INDICATED, PRIOR TO INSULATING DUCTWORK. THE ELECTRICAL ROOM SHALL BE PRESSURISED. IDENTIFY ALL LEAKAGE POINTS (USING SMOKE PENCIL OR SIMILAR METHOD) AND SEAL AIR TIGHT. RE-PERFORM LEAKAGE TEST IN THE PRESENCE OF THE CONTRACT ADMINISTRATOR. THE CONTRACT ADMINISTRATOR SHALL APPROVE THE LEAK TEST PRIOR TO DUCT


LEGEND:

EXISTING

BALANCE DAMPER

EXTERNALLY INSULATED DUCTWORK

- NECK SIZE




KGS GROUP CONSULTING ENGINEERS & PROJECT MANAGERS B.M. ELEV. **CH2MHILL** CHECKED BY PSS RED APPROVED BY RELEASED FOR CONSTRUCTION: HOR. SCALE: AS SHOWN VERTICAL: CONSULTANT DRAWING NO. 01 ISSUED FOR TENDER FEB.15/08 RED

DATE BY DATE

NO. REVISIONS

00/00/07



1-0101P-M0004-001

Winnipeg

THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT

NEWPCC - CIRCULAR PRIMARY CLARIFIER REFURBISHMENT

ELECTRICAL ROOM NEW VENTILATION

001 COMPUTER FILE NAME 1-0101P-M0004-001 CITY DRAWING NUMBER 1-0101P-M0004-001

SHEET