



- LEGEND**
- PULL STATION C/W ADDRESSABLE MONITOR MODULE FMM-101A
  - ADDRESSABLE MONITOR MODULE FMM-1A
  - ⊙ ADDRESSABLE SMOKE DETECTOR FSP-851A
  - ⊕ ADDRESSABLE HEAT DETECTOR FST-851A
  - ADDRESSABLE RELAY MODULE FRM-1A
  - ⊠ FIRE ALARM HORN
  - ⊞ END OF LINE RESISTOR
  - ⊞ ADDRESSABLE DUCT SMOKE DETECTOR
  - NDLK27 ADDRESSABLE DEVICE ADDRESS
  - ⊞ SPRINKLER WATERFLOW SWITCH
  - D- SPRINKLER ISOLATION VALVE

AND  
LOCATED IN STAIRWEL  
ON BASEMENT LEVEL

TUNNEL  
Notifier NFS-640 Fire  
Alarm Control Panel,  
Remote Panel located  
in Building B

BLDG B STORAGE TRACKS - FIRE ALARM LAYOUT



PROJECT		THE CITY OF WINNIPEG TRANSIT GARAGE BLDG B STORAGE TRACKS	
TITLE		FIRE ALARM DETAIL	
DATE	BY	SCALE	CONTRACT
04.13.2008	AS-BUILT	1:100	
DRAWN		BY	DATE
CHECK		BY	DATE
APPROVED		VFPND SYSTEMS GROUP	
VFPND		VFPND SYSTEMS GROUP	