



## 447-2008 ADDENDUM 1

### REPLACEMENT OF AIR CONDITIONER COMPRESSOR

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: June 25, 2008  
BY: Ken M. Stelmack, C.P.P., C.P.M., C.I.M.  
TELEPHONE NO. (204) 986-2293

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20070419

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 7 of Form A: Bid may render your Bid non-responsive.**

---

#### **PART E – SPECIFICATIONS**

Add: E2.7 The contractor will be required to install a replaceable core suction filter and liquid line filter. After the compressor is first run, the contractor will check the filter for contamination, and will change the filter up to three times as required to clear the refrigerant system of any accumulated dirt or contamination and will report the final pressure drop across the filter. The contractor will also report on the acid and moisture content of the refrigerant at the completion of the work.