

## LUMINAIRE SCHEDULE



Project: Rehabilitation of Bournais Wastewater Pumping Station

Bid Opportunity Number: 901-2008

SMS Job Number: 07-213-01

FIXT. TYPE	LAMPS	VOLTAGE	DESCRIPTION	NOTES	APPROVED MANUFACTURERS
PC	2 F32 T8	120V	2L FIBERGLASS REINFORCED POLYESTER HOUSING C/W GASKETTED ACRYLIC LENS LATCHED TO HOUSING		C &M: VCAW-232 CFI: VT-248 LITHONIA: FCD232 METALUX: VT2-232-DR PEERLESS: DCC-4-232
XP	A21 100W	120V	EXPLOSION PROOF, FOR WET LOCATIONS APPROVED AS CLASS 1, ZONE 1, GROUP IIA INCANDESCENT 100W		APPLETON: AEC1075-CG CROUSE -HINDS: EVICX2301
SD	HPS 150W	120V	DIE-CAST ALUMINUM HOUSING UV RESISTANT POLYCARBONATE LENS C/W PHOTOCELL		KEENE: CWS-150AL-1 LITHONIA: TWP 150S 120 PE LPI