



237-2009 ADDENDUM 1

Construction of Valve Chamber Superstructure, Installation of Valve Actuators and Associated Works

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: May 19, 2009
BY: G. Blazek
TELEPHONE NO. (204) 284-0580

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, May 22, 2009.

PART E – SPECIFICATIONS

Add: NMS 011100 Clause 3.1.2

Excavate to expose buried cover at LAV1 as required. Details of existing Chamber are provided on Drawing ME-59 - Historic Drawing.

Add: NMS 079000 Clause 2.1.1.3

Horizontal Joints – Buried Service: One Component Self-levelling.

Add: NMS 079000 Clause 2.1.8

Type A: One-component, self-leveling, premium-grade, polyurethane sealant, CAN/CGSB 19.13-M87, Classification C-1-25-B-N, Sikaflex 1c SL or Vulchem 45.

DRAWINGS

Replace: 237-2009 _Drawing_D-11783_R0 with 237-2009 _Addendum_1 Drawing D-11783_R1

Add: Drawing ME-59 - Historic Drawing