

PC Name	N1 Address	Actual Type
PC1	1:100:0	PC

NC Name	N1 Address	Actual Type	N2 Port
NC-4	1:4:0	NC	1

Hardware Dev	Sys\Obj Name	Dnld Type	Act1 Type	Slot Type	Slot Nmbr	Sub Sit	Software Sys\Obj Name	S/W Type	Point Type
1	NC4-HW\DCM-1	DCM	101	Input	1		CHILLER\CWS-T	AI	
				Input	2		CHILLER\CWR-T	AI	
				Input	3		CHILLER\TWS-T	AI	
				Input	4		CHILLER\TWR-T	AI	
2	NC4-HW\XRL-2	XRL	XRL	Input	1		SF-1\SF1-S	BI	SINGLE
				Input	2		FIRE\FIRE_PNL	BI	SINGLE
				Input	3		BOILER\H-PS	BI	SINGLE
				Input	4		CHILLER\C-PS	BI	SINGLE
				Input	5		SF-1\HC-FLOW	BI	SINGLE
				Input	6		SF-1\FIRE-STA	BI	SINGLE
				Input	7		SF-1\KEF-S	BI	SINGLE
				Input	8		EXH-FANS\EF04a-S	BI	SINGLE
				Output	1		SF-1\SF1-C	BO	
				Output	2		CHILLER\CH-C	BO	
				Output	3		BOILER\BOILERS	BO	
				Output	4		BOILER\SYSTEM	BO	
				Output	8		EXH-FANS\EF04a-C	BO	
3	NC4-HW\XBN-3	XBN	XBN	Input	1		BOILER\STAGE_01	BI	SINGLE
				Input	2		BOILER\STAGE_02	BI	SINGLE
				Input	3		BOILER\STAGE_03	BI	SINGLE
				Input	4		BOILER\STAGE_04	BI	SINGLE
4	NC4-HW\DCM-4	DCM	101	Input	1		SF-1\OA-T	AI	
				Input	2		SF-1\MA-T	AI	
				Input	3		BOILER\HWS-T	AI	
				Input	4		SF-1\COMP-T	AI	
				Input	5		SF-1\RA-T	AI	
				Input	6		SF-1\SA-T	AI	
				Input	7		SF-1\Basement	AI	
				Input	8		SF-1\Ground	AI	
				Input	9		BOILER\BWS-T	AI	
				Input	10		BOILER\BWR-T	AI	
				Output	2		SF-1\MA-DMP	AOD	PROP
				Output	4		SF-1\HC-VLV	AOD	PROP
				Output	6		BOILER\HW-VLV	AOD	PROP
				Loop	1		SF-1\HC-CTL	PIDL	
				Loop	2		SF-1\DMP-CTRL	PIDL	
				Loop	3		SF-1\MAPLL	PIDL	
				Loop	5		BOILER\HW-CTRL	PIDL	
5	NC4-HW\XRL-5	XRL	XRL	Input	1		XRL5\BI-01	BI	SINGLE
				Input	2		XRL5\BI-02	BI	SINGLE
				Input	3		XRL5\BI-03	BI	SINGLE
				Input	4		XRL5\BI-04	BI	SINGLE
				Input	5		XRL5\BI-05	BI	SINGLE

Hardware Dev Sys\Obj Name	Dnld Type	Act1 Type	Slot Type	Slot Nmbr	Sub Slit	Software Sys\Obj Name	S/W Type	Point Type
6 NC4-HW\XRL-6	XRL	XRL	Input	6		XRL5\BI-06	BI	SINGLE
			Input	7		XRL5\BI-07	BI	SINGLE
			Input	8		XRL5\BI-08	BI	SINGLE
			Output	1		XRL5\BO-01	BO	
			Output	2		XRL5\BO-02	BO	
			Output	3		XRL5\BO-03	BO	
			Output	4		XRL5\BO-04	BO	
			Output	5		XRL5\BO-05	BO	
			Output	6		XRL5\BO-06	BO	
			Output	7		XRL5\BO-07	BO	
			Output	8		XRL5\BO-08	BO	
			Input	1		EXH-FANS\EF01-S	BI	SINGLE
			Input	2		EXH-FANS\EF02-S	BI	SINGLE
			Input	3		EXH-FANS\EF03-S	BI	SINGLE
			Input	4		EXH-FANS\EF04-S	BI	SINGLE
			Input	5		EXH-FANS\EF05-S	BI	SINGLE
Input	6		EXH-FANS\EF06-S	BI	SINGLE			
Input	7		EXH-FANS\EF07-S	BI	SINGLE			
Input	8		EXH-FANS\EF08-S	BI	SINGLE			
Output	1		EXH-FANS\EF01-C	BO				
Output	2		EXH-FANS\EF02-C	BO				
Output	3		EXH-FANS\EF03-C	BO				
Output	4		EXH-FANS\EF04-C	BO				
Output	5		EXH-FANS\EF05-C	BO				
Output	6		EXH-FANS\EF06-C	BO				
Output	7		EXH-FANS\EF07-C	BO				
Output	8		EXH-FANS\EF08-C	BO				
7 NC4-HW\XRL-7	XRL	XRL	Input	1		EXH-FANS\EF09-S	BI	SINGLE
			Input	2		EXH-FANS\EF10-S	BI	SINGLE
			Input	3		EXH-FANS\EF11-S	BI	SINGLE
			Input	4		EXH-FANS\EF24-S	BI	SINGLE
			Input	5		EXH-FANS\EF29-S	BI	SINGLE
			Input	6		G-OVRD\OVRD-S	BI	SINGLE
			Input	7		PLAZMA\FUMEHOOD	BI	SINGLE
			Input	8		EXH-FANS\EF25-S	BI	SINGLE
			Output	1		EXH-FANS\EF09-C	BO	
			Output	2		EXH-FANS\EF10-C	BO	
			Output	3		EXH-FANS\EF11-C	BO	
			Output	4		EXH-FANS\EF24-C	BO	
			Output	5		EXH-FANS\EF29-C	BO	
			Output	6		CARPLUG2\S-PLUG	BO	
			Output	7		CARPLUG2\W-PLUG	BO	
			Output	8		EXH-FANS\EF25-C	BO	
8 NC4-HW\XRL-8	XRL	XRL	Input	1		BodyShop\STATUS	BI	SINGLE
			Input	2		XRL8\BI-02	BI	SINGLE
			Input	3		XRL8\BI-03	BI	SINGLE
			Input	4		XRL8\BI-04	BI	SINGLE
			Input	5		XRL8\BI-05	BI	SINGLE
			Input	6		XRL8\BI-06	BI	SINGLE
			Input	7		XRL8\BI-07	BI	SINGLE
			Input	8		BodyShop\BUTTON	BI	SINGLE

Hardware Dev Sys\Obj Name	Dnld Type	Act1 Type	Slot Type	Slot Nmbr	Sub Slit	Software Sys\Obj Name	S/W Type	Point Type
			Output	1		BodyShop\COMMAND	BO	
			Output	2		XRL8\BO-02	BO	
			Output	3		XRL8\BO-03	BO	
			Output	4		XRL8\BO-04	BO	
			Output	5		XRL8\BO-05	BO	
			Output	6		XRL8\BO-06	BO	
			Output	7		XRL8\BO-07	BO	
			Output	8		XRL8\BO-08	BO	
9 NC4-HW\LCP-1	LCP	LCP						
				0		MUA-UNTS\MUA-1	CS/ASC	
10 NC4-HW\LCP-2	LCP	LCP						
				0		MUA-UNTS\MUA-2	CS/ASC	
11 NC4-HW\LCP-3	LCP	LCP						
				0		MUA-UNTS\MUA-3	CS/ASC	
12 NC4-HW\LCP-4	LCP	???						
13 NC4-HW\LCP-5	LCP	LCP						
				0		MUA-UNTS\MUA-5	CS/ASC	
14 NC4-HW\UNT-14	UNT	UNT						
				1		MUA-UNTS\MUA6-S	BI	
				2		MUA-UNTS\FLAME-06	BI	
				2		MUA-UNTS\MUA6-HTG	BO	
				4		MUA-UNTS\A6-T	AI	
				3		MUA-UNTS\SA6-T	AI	
				2		MUA-UNTS\GAS-6	AOS	
				1		MUA-UNTS\DMPR-6	AOS	
				0		MUA-UNTS\MUA-6	CS/ASC	
15 NC4-HW\LCP-7	LCP	LCP						
				0		MUA-UNTS\MUA-7	CS/ASC	
16 NC4-HW\UNT-16	UNT	UNT						
				1		SF-2\SF-S	BI	
				1		SF-2\SF-C	BO	
				197		SF-2\SHUTDOWN	BO	
				204		SF-2\HTG-LO	BO	
				205		SF-2\CLG-LO	BO	
				199		SF-2\ECON-ENA	BO	
				1		SF-2\RET-T	AI	
				2		SF-2\SAT-T	AI	
				3		SF-2\MA-T	AI	
				2		SF-2\CLG-C	AOS	
				1		SF-2\HTG-C	AOS	
				3		SF-2\MAD-CMD	AOS	
				0		SF-2\SF-2	CS/ASC	
17 NC4-HW\UNT-17	UNT	UNT						
				0		COMP_AIR\COMP_SYS	CS/ASC	

Counts for NC-4

													Totals	
Hardware														
DCM	XBN	XRM	XRL	LCD	DSC	N2O	SYS91	FPU	DSC85	IFC	AC			
2	1	0	5	0	0	3	6	0	0	0	0			
LON														
0													17	
Software														
AI	AOD	AOS	BI	BO	LCG	PIDL	ACM	AD	BD	CS/DSC	CS/ASC	ZONE	RDR	MC
19	3	5	47	43	0	4	0	80	41	0	8	0	0	0
MSI MSO MSD														
0 0 0													250	
Features														
DLLR Processes														
0 24													24	
												Grand Total for this NC:	291	

Counts for all NC's

													Totals	
Hardware														
DCM	XBN	XRM	XRL	LCD	DSC	N2O	SYS91	FPU	DSC85	IFC	AC			
2	1	0	5	0	0	3	6	0	0	0	0			
LON														
0													17	
Software														
AI	AOD	AOS	BI	BO	LCG	PIDL	ACM	AD	BD	CS/DSC	CS/ASC	ZONE	RDR	MC
19	3	5	47	43	0	4	0	80	41	0	8	0	0	0
MSI MSO MSD														
0 0 0													250	
Features														
DLLR Processes														
0 24													24	
												Grand Total for all NC's:	291	

...END...