



MANUAL CHANGEOVER VALVE OPERATION

	SUMMER	WINTER
HV1	CLOSED	OPEN
HV2	OPEN	CLOSED
HV3	CLOSED	OPEN
HV4	OPEN	CLOSED

FAN COIL WATER RESET

OUTDOOR AIR	SUPPLY WATER
-30	200
65	110

DRAWING TITLE
FT. ROUGE ADMINISTRATION
HOT WATER/CHILLED WATER
SYSTEM

PROJECT
WINNIEG TRANST
ADMINISTRATION AND G SECTION
METASYS FACILITY
MANAGEMENT SYSTEM

JOHNSON CONTROLS
Systems & Services Division

JOHNSON CONTROLS LTD
800 MORAY STREET
WINNIEG, MANITOBA
R3J 3Y9
204-855-8300

FILE: HWCHSCHE

REFERENCE DRAWING NO.	NO.	REVISION-LOCATION	DATE	BY
1	AS BUILT			

CONTRACT NUMBER
91098-5006
DRAWING NUMBER
1501-39