



LEGEND

Point Desc. DC-9100 DIGITAL CONTROLLER
 Term. Number TERMINATIONS

CO2 - CARBON DIOXIDE SENSOR

CR - 24VAC CONTROL RELAY*

DPS - DIFFERENTIAL PRESSURE SWITCH

DPT - DIFFERENTIAL PRESSURE TRANSDUCER*

TE - 1000Ω RESISTIVE TEMPERATURE ELEMENT

VRT - VOLTAGE IN/RESISTIVE OUT TRANSDUCER*

* - MOUNTED AT MUA UNIT IN 20" x 20" DDC CONTROL PANEL (REFER DWG. 1501-47)

(2) - 18/2 TWISTED & SHIELDED CABLE

(4) - 22/4 TWISTED CABLE

DRAWING TITLE
 FT. ROUGE G SECTION
 MUA-1

SALES ENGR	PROJECT MGR	APPL. ENGR	DRAWN	APPROVED	DATE	BY
BH	RG	RG	BT	CV	01/27/92	BY

NO.	REVISION	LOCATION	ECN	DATE	BY
1	PROP.	HTG AO-1		02/08/92	CH

PROJECT	MANUFACTURER	CONTRACT NUMBER
WINNIEG TRANSIT ADMINISTRATION AND G SECTION METASTAS FACILITY MANAGEMENT SYSTEM	JOHNSON CONTROLS LTD 800 MURRAY STREET WINNEPEG, MANITOBA R3J 3Y9 204-885-9300	91098-5006 1501-41A

FILE: MUA1SYS