

709-2009 ADDENDUM NO. 1

SOUTH END WATER POLLUTION CONTROL CENTRE INSTALLATION OF OUTFALL PIPE, EFFLUENT SAMPLING FACILITY AND ASSOCIATED WORKS CONTRACT NO. 2

ISSUED: October 22, 2009

BY: Hartley Katz, C.E.T., P. Eng. TELEPHONE NO. (204) 489-5900

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission deadline is 12:00 noon Winnipeg time, **November 4, 2009.**

Revise: B3.1 to read: Further to C3.1, the Contract Administrator or an authorized representative will be available at

the Site from 10:00 A.M. to 11:00 A.M. on October 29, 2009 to provide Bidders access to the

Site.

Add: B3.3: The Bidder is advised that this meeting will be held to discuss seasonal/daily flows leaving the

SEWPCC.

Add: B3.4 The Bidder shall not be entitled to rely on any information or interpretation received at the Site

investigation unless that information or interpretation is the Bidder's direct observation, or is

provided by the Contract Administrator in writing.

PART E - SPECIFICATIONS

Revise: E39.2 (b) (v) to read: Two Speed Motor: 0.25 HP, 120 V, 1 Ph., Hazardous location, corrosion resistant motor

Revise: E39.2 (f) (i) to read: All control damper operators shall be electric 120 VAC spring return

Add: E39.2 (f) (i) 4. Dry side damper motor enclosure to be EEMAC 12 Rated

Add: E39.2 (f) (i) 5. Wet side damper motor enclosure to be EEMAC 4X Rated

Revise: E43.1 (c) (i) to read: Sample line stilling pipe – Type 316 stainless steel

Revise: E46.2 (k) (i) to read: Ingersoll Rand **DD2T2**