



831-2009 ADDENDUM 1

SUPPLY, INSPECTION OF INSTALLATION, AND COMMISSIONING OF BUTTERFLY VALVES, FLOW METER AND MISCELLANEOUS EQUIPMENT

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: December 3, 2009
BY: M. McDonald
TELEPHONE NO. (204) 928-7422

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise: E6.3.2 to read:

Actuator Sizing

- (a) The electric actuators shall be sized to provide the torque required to close or open the valve for full bi-directional flow at a differential pressure equal to the design pressure of the valve identified in E 5.2 (b)(xiv). The maximum thrust output of the actuator shall not exceed the valve shaft torque capability as indicated in the latest revision of AWWA Standard C504.