


GENERAL NOTES

- A. ALL EXISTING ELECTRICAL OUTLETS, CONDUITS, WIRING, ETC. TO BE REMOVED NOT NECESSARILY SHOWN ON DRAWINGS. DIVISION 16 SHALL REMOVE ALL UNNECESSARY EXISTING ELECTRICAL OUTLETS, FIXTURES, WIRING, CONDUIT, ETC. IN PORTIONS OF EXISTING BUILDING WHICH ARE BEING ALTERED AND REMODELLED. ANY ELECTRICAL OUTLETS, FIXTURES, WIRING, ETC. ADJACENT TO THE AREA BEING RENOVATED WHICH ARE NECESSARY FOR THE OPERATION OF THE EXISTING BUILDING SHALL BE RELOCATED AS REQUIRED AND RECONNECTED TO SUIT. DIVISION 16 TO ADVISE GENERAL CONTRACTOR TO PATCH, REPAIR AND PAINT EXISTING WALLS WHERE EXISTING ELECTRICAL DEVICES HAVE BEEN REMOVED (INSTALLATION OF BLANK COVERPLATES OVER ABANDONED OUTLETS IS NOT ACCEPTABLE).
- B. FOR ALL EXISTING ELECTRICAL DEVICES, FIXTURES, EQUIPMENT, ETC. THAT ARE TO BE REMOVED, REMOVE EXISTING CONDUIT, WIRING, ETC. BACK TO SOURCE UNLESS OTHERWISE INDICATED.

DRAWING NOTES

- 1. DISCONNECT AND REMOVE EXISTING DETECTOR AND TURN OVER TO LANDLORD.
- 2. DISCONNECT AND REMOVE EXISTING RECEPTACLE.
- 3. DISCONNECT AND REMOVE EXISTING 12' AIRCRAFT CABLE SUSPENDED INDIRECT FIXTURE AND TURN OVER TO LANDLORD.
- 4. EXISTING STROBE/BELL TO BE RELOCATED. REFER TO DRAWING E2.0.

1 PART MAIN FLOOR DEMOLITION PLAN - ELECTRICAL
 E0.1 SCALE: 1:100



FIRE DETECTION		LIGHTING	
☉	SMOKE DETECTOR	⎓	FLUORESCENT FIXTURE, A1-PANEL AND CIRCUIT, α-CONTROL
☒	SMOKE ALARM	⎓	LIGHT FIXTURE CONNECTED TO EMERGENCY POWER OR (TYPICAL FOR ALL LIGHT FIXTURES)
☉	STROBE/BELL	○	DOWN LIGHT
SYSTEMS AND COMMUNICATION		SWITCHING	
∇	VOICE DATA OUTLET C/W 3/4" CONDUIT STUBBED INTO ACCESSIBLE CEILING SPACE	Ⓞ	OCCUPANCY SENSOR SWITCH
RECEPTACLE AND POWER		ABBREVIATIONS (ADJACENT TO SYMBOL DENOTES)	
Ⓜ	DUPLEX RECEPTACLE	P	PEDESTAL MOUNTED
Ⓜ	QUADRAPLEX RECEPTACLE	R	EXISTING TO BE RELOCATED
Ⓜ	JUNCTION BOX		
⎓	RECESSED MOUNTED PANEL		

NOTE
 ELECTRICAL SHOWN DASHED IS EXISTING TO BE DISCONNECTED AND REMOVED UNLESS OTHERWISE NOTED.
 ELECTRICAL SHOWN FADED BACK IS EXISTING TO REMAIN UNLESS OTHERWISE NOTED.
 ELECTRICAL SHOWN SOLID IS NEW TO BE INSTALLED UNLESS OTHERWISE NOTED.



APEGM
 Certificate of Authorization
 SMS Engineering Ltd.
 No. 166 Expiry: April 30, 2010

SMS ENGINEERING
 SMS Engineering Ltd. Consulting Engineers
 770 Bradford Street Winnipeg MB Canada R3H 0N3
 Telephone 204.775.0291 Fax 204.772.2153
 sms@smsgeng.com

Project Title
RENOVATIONS TO ENGINEERING AND RECORD STORAGE AREAS - WATER AND WASTE OFFICES
 1199 PACIFIC AVE, WINNIPEG MB

Drawing Title
PART MAIN FLOOR DEMOLITION PLAN ELECTRICAL

Drawn By CM	Checked By CM	Approved By BDL
Scale 1:100	Date DECEMBER 2009	Project No. 09-203-01
Revision Number 0	Drawing Number E0.1	Sheet Order 1 OF 10