



DRAWING NOTES

1. RELOCATE EXISTING 2'X4' DIRECT/INDIRECT FIXTURE AS SHOWN; EXTEND WIRING IN CONDUIT AS REQUIRED.
2. NEW WALL MOUNTED OCCUPANCY TO MATCH EXISTING. OCCUPANCY SENSOR TO CONTROL ALL LIGHTS IN ROOM; REWIRE RELOCATED LIGHT FIXTURES AS REQUIRED.
3. EXISTING OCCUPANCY SENSOR TO CONTROL ALL LIGHTS IN ROOM; REWIRE RELOCATED LIGHT FIXTURES AS REQUIRED.
4. RELOCATED 2'X4' DIRECT/INDIRECT FIXTURE FROM TV ROOM/RESOURCE LIBRARY. REFER TO DRAWING E0.2. CLEAN FIXTURE AND RE-LAMP. WIRE AND CONNECT TO EXISTING 347V LIGHTING CIRCUIT SERVING AREA WITH CAPACITY.

1 PART MAIN FLOOR PLAN - LIGHTING
 E1.2 SCALE: 1:100



APEGM
 Certificate of Authorization
 SMS Engineering Ltd.
 No. 166 Expiry: April 30, 2010

SMS ENGINEERING

SMS Engineering Ltd. Consulting Engineers
 770 Bradford Street Winnipeg MB Canada R3H 0N3
 Telephone 204.775.0291 Fax 204.772.2153
 sms@smseng.com

Project Title
**RENOVATIONS TO ENGINEERING
 AND RECORD STORAGE AREAS -
 WATER AND WASTE OFFICES**
 1199 PACIFIC AVE, WINNIPEG MB

Drawing Title
**PART MAIN FLOOR PLAN
 LIGHTING**

| | | |
|-----------------------------|-------------------------------|--------------------------|
| Drawn By CM | Checked By CM | Approved By BDL |
| Scale 1:100 | Date DECEMBER 2009 | Project No. 09-203-01 |
| Revision Number 0 | Drawing Number E1.2 | Sheet Order 6 OF 10 |