



DRAWING NOTES

1. RELOCATE EXISTING STROBE/BELL AS SHOWN; EXTEND EXISTING WIRING IN CONDUIT AS REQUIRED.
2. WIRE AND CONNECT RECEPTACLES TO DEDICATED 15A-1P BREAKER, CIRCUIT 5B-68 IN EXISTING PANEL 5B.
3. WIRE AND CONNECT RECEPTACLES TO DEDICATED 15A-1P BREAKER, CIRCUIT 5B-69 IN EXISTING PANEL 5B.
4. WIRE AND CONNECT RECEPTACLES TO DEDICATED 15A-1P BREAKER, CIRCUIT 5B-70 IN EXISTING PANEL 5B.
5. WIRE AND CONNECT RECEPTACLES TO DEDICATED 15A-1P BREAKER, CIRCUIT 5B-71 IN EXISTING PANEL 5B.

1 PART MAIN FLOOR PLAN - POWER & SYSTEMS
 SCALE: 1:100



APEGM
 Certificate of Authorization
 SMS Engineering Ltd.
 No. 166 Expiry: April 30, 2010

SMS ENGINEERING
 SMS Engineering Ltd. Consulting Engineers
 770 Bradford Street Winnipeg MB Canada R3H 0N3
 Telephone 204.775.0291 Fax 204.772.2153
 sms@smseng.com

Project Title
**RENOVATIONS TO ENGINEERING
 AND RECORD STORAGE AREAS -
 WATER AND WASTE OFFICES**
 1199 PACIFIC AVE, WINNIPEG MB

Drawing Title
**PART MAIN FLOOR PLAN
 POWER & SYSTEMS**

Drawn By CM	Checked By CM	Approved By BDL
Scale 1:100	Date DECEMBER 2009	Project No. 09-203-01
Revision Number 0	Drawing Number E2.0	Sheet Order 7 OF 10