



148-2010 ADDENDUM 1

Removal of Fuel Tanks and Associated Infrastructure at Two City of Winnipeg Fuel Sites

ISSUED: March 12, 2010
BY: Ajaleigh Williams
TELEPHONE NO. (204) 986-7879

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph ^ of Form A: Bid may render your Bid non-responsive.

PART A – BID SUBMISSION

Replace: 148-2010 Bid Submission with 148-2010 Addendum 1- Bid Submission. The following is a summary of changes incorporated in the replacement Bid Submission:

Form B(R1): The backfilling with excavated material is now to be included in the price for items 1(a) and 2 (a), and the additional backfill is now to be bid separately as items 1 (c) and 2 (c).

PART D – SUPPLEMENTAL CONDITIONS

- Revise: D12.1 The Contractor shall achieve critical stages of the Work in accordance with the following requirements:
 - (a) All work at 735 Assiniboine Park Drive, with the exception of the soil report which may be submitted up to 2 weeks following, shall be completed by May 17, 2010.
- Revise: D13.1 With exception to the soil reports, which may be submitted up to 2 weeks following, the Contractor shall achieve Total Performance by May 24, 2010.

PART E – SPECIFICATIONS

- Revise: E2.1 (b)(i) Backfill with excavated material and top with additional fill material as required to 150 mm below finished grade. The fill will be placed in 300 mm lifts and compacted to 100 % Proctor Density. For the purposes of bidding, assume that 25 m3 of additional fill shall be placed in the excavated area. If at the time of filling this amount of work is deemed not to be required, it will be eliminated from the cost billed to the City. The additional fill material, if required, shall be **class 2 backfill** in accordance with City of Winnipeg *Standard Constructions Specifications CW 2030 R-7*.
- Revise: E2.1 (b) (ii) Granular and Compaction: The Contractor shall place 150 mm of granular and compact to 100% proctor density to finished grade. The granular shall be **Base Course Material** in accordance with City of Winnipeg *Standard Constructions Specifications CW 3110 R-10*.

Revise: E3.1 (c)(i)

Backfill with excavated material and top with additional fill material as required to 150 mm below finished grade. The fill will be placed in 300 mm lifts and compacted to 100 % Proctor Density. For the purposes of bidding, assume that 25 m³ of additional fill shall be placed in the excavated area. If at the time of filling this amount of work is deemed not to be required, it will be eliminated from the cost billed to the City. The additional fill material, if required, shall be **class 2 backfill** in accordance with City of Winnipeg *Standard Construction Specifications CW 2030 R-7*.

Revise: E3.1 (c) (ii)

Granular and Compaction: The Contractor shall place 150 mm of granular and compact to 100% proctor density to finished grade. The granular shall be **Base Course Material** in accordance with City of Winnipeg *Standard Construction Specifications CW 3110 R-10*.