
LOWER LEVEL FLOOR PLAN




- 1. MOUNT LEVEL SWITCHES TO ACTIVATE WITH 100mm WATER LEVEL.
- 2. FCV-101, 102 MOTOR LOCATED UPPER FLOOR.

	LUMINAIRE SCHEDULE										
TYPE	MANUFACTURER	CAT. NO.	LAMP	VOLTAGE	REMARKS						
A	LITHONIA	DMW 28T5 120 GEB10PS	2 x 28W T-5	120V 1Ø	RAPID START ENCLOSED FIBREGLASS FLUORESCENT LUMINAIRE						
В	LITHONIA	TWRIC 70M 120 CSA PE TWRICWG FCV	1 x 70W MH	120V 1Ø	MINI WALL PACK WITH VERTICAL CUT-OFF, INTEGRAL PHOTOCELL AND WIREGUARD						



UPPER LEVEL FLOOR PLAN



- 1. TYPE 'A' LUMINAIRES IN THE UPPER LEVEL TO BE MOUNTED 2200mm AFF.
- 2. WIRING SHALL BE IN PVC CONDUITS UNLESS INDICATED OTHERWISE.
- 3. SUMP PIT RECEPTACLE TO BE MOUNTED 600mm ABOVE TOP OF SUMP.
- 4. LUMINAIRES SHALL COME COMPLETE WITH LAMPS.
- 5. SEE MECHANICAL DRAWINGS FOR HVAC CONTROL WIRING. HVAC CONTROL PANEL, EXHAUST FAN EF-1 AND CONTROL WIRING BY MECHANICAL CONTRACTOR.

GFI	GFCI RECEPTACLE
	SURFACE MOUNTED FLUORESCENT
A	WALL MOUNTED LIGHT FIXTURE
₩-	SPST SWITCH
⋽	UNIT HEATER
М	MOTORIZED DAMPER (SUPPLIED BY OTHERS)
	SELF POWERED EXIT SIGN / EMERGENCY LIGHTING
■DC	DOOR CONTACTS

DISCONNECT SWITCH

<u>LEGEND</u>

BID OPPORTUNITY NO. 16-2010



LOCATION APPROVED UNDERGROUND STRUCTURES		
SUPR. U/G STRUCTURES DATE COMMITTEE		
NOTE: LOCATION OF UNDERGROUND STRUCTURES AS SHOWN ARE BASED ON THE BEST INFORMATION AVAILABLE. BUT NO		
GUARANTEE IS GIVEN THAT ALL EXISTING UTILITIES ARE SHOWN OR THAT THE GIVEN LOCATIONS ARE EXACT. CONFIRMATION OF		
EXISTENCE AND EXACT LOCATION OF ALL SERVICES MUST BE OBTAINED FROM THE INDIVIDUAL UTILITIES BEFORE PROCEEDING	0	ISSUED FOR CONSTI
WITH CONSTRUCTION.		REVISIONS

VED RES			AECOM	Th no ag go		
					AECON	go an dra Do sta
CTURES					DESIGNED BY	LCI
TING GIVEN					DRAWN BY	SCI
TON OF ALL THE					HOR. SCALE VERT. SCALE	1:40
EDING	0	ISSUED FOR CONSTRUCTION	10/02/08	SCK		
	NO.	REVISIONS	YY/MM/DD	BY	DATE 10)/02/0

This drawing has been prepared for the use of AECOM's client and may not be used, reproduced or relied upon by third parties, except as agreed by AECOM and its client, as required by law or for use by governmental reviewing agencies. AECOM accepts no responsibility, and denies any liability whatsoever, to any party that modifies this drawing without AECOM's express written consent. Do not scale this document. All measurements must be obtained from stated dimensions. CHECKED BY LK

FEB. 9, 2010

APPROVED

RELEASED FOR CONSTRUCTION

ISSUED FOR CONSTRUCTION WAS SEALED BY B. L. MOORE AND DATED FEB. 8, 2010

CONSULTANT DRAWING NO.

D265-250-00_01-E-0002_RX.dwg

THE CITY OF WINNIPEG **WATER AND WASTE DEPARTMENT**

BRANCH I AQUEDUCT VALVE CHAMBER AT McPHILLIPS STREET **PUMPING STATION ELECTRICAL**

LOWER & UPPER LEVEL FLOOR PLAN

CITY DRAWING NUMBER D-11934 °