

U/G SERVICE NOTES:

LEGEND	
	PROPERTY LINE
	MTS
	GAS
	WATER MAIN
	WWS
I	STREET LIGHT
←●	PEDESTRIAN CROSSING SIGNA
<u> </u>	STREET SIGN
0	MANHOLE
	CATCH BASIN
-¢-	FIRE HYDRANT
Q <b>, ⊗</b>	VALVES
۲	SURVEY BAR
	NEW CONCRETE / PAVING STONE
TC	TOP OF CURB
BC	BOTTOM OF CURB
<b>+</b> 231.81	PROPOSED ELEVATION
1.7%	DRAINAGE SLOPE
	RELOCATED CATCH BASIN
+222.00)	EXISTING SURVEY POINT AND GRADE

## NOTES

1. ALL ELEVATIONS ARE IN METRES UNLESS OTHERWISE SPECIFIED. 2. CONFIRM GRADES WITH CONTRACT ADMINISTRATOR PRIOR TO INSTALLATION. 3. ALL NEW ASPHALT AND PAVED AREAS TO MEET EXISTING GRADES FLUSH AND TRUE.

4. REPORT ANY ON SITE DISCREPANCIES TO THE CONTRACT ADMINISTRATOR IMMEDIATELY

2	Issued for Tender	June 3, 2010
1	Released for Review	March 10, 2010
No.	Revision	Date

THIS DRAWING MUST NOT BE SCALED.

- THE GENERAL CONTRACTOR SHALL VEREY ALL DIMENSIONS, DATUMS AND LEVELS PRIOR TO COMMENCEMENT OF WORK. ALL ERRORS AND OMISSIONS TO BE REPORTED IMMEDIATELY TO THE LANDSCAPE
- VARIATIONS & MODIFICATIONS TO WORK SHOWN ON THESE DRAWINGS SHALL NOT BE CARRIED OUT WITHOUT WRITTEN PERMISSION FROM THE LANDSCAPE ARCHITECT
- THIS DRAWING IS THE EXCLUSIVE PROPERTY OF THE LANDSCAPE APCHITECTS AND CAN BE REPRODUCED ONLY WITH THE PERMISSION OF THE LANDSCAPE ARCHITECTS, IN WHICH CASE THE REPRODUCTION MUST BEAR THEIR NAME AS LANDSCAPE ARCHITECTS.

## EDMONTON STREET WEST SIDEWALK PORTAGE TO GRAHAM Streetscape Redevelopment Project Title

1. LOCATIONS OF UNDERGROUND STRUCTURES AS SHOWN ARE BASED ON THE BEST INFORMATION AVAILABLE BUT NO GUARANTE IS GIVEN THAT ALL EXISTING ARE SHOWN OR THAT THE GIVEN LOCATIONS ARE EXACT. CONFIRMATION OF EXISTENCE AND EXACT LOCATION OF ALL SERVICES MUST BE OBTAINED FROM THE INDIVIDUAL UTILITIES BEFORE PROCEEDING WITH CONSTRUCTION. ANY ENCUMBERATORS SHALL BE REPORTED TO THE CONTRACT ADMINISTRATOR IMMEDIATELY.

2. DUCTS CONTAIN FIBRE OPTIC CABLES AND MUST BE EXCAVATED IN ACCORDANCE WITH UTILITY'S EXPRESS REQUIREMENTS. THE CONTRACTOR SHALL CONTACT THE UTILITY AT LEAST SEVEN DAYS PRIOR TO EXCAVATION.

3. A MINIMUM CLEARANCE OF 1.0 METER MUST BE PROVIDED BETWEEN THE UNDERSIDE OF ANY EXISTING WATERMAIN OR SEWERMAIN AND THE TOP OF PROPOSED WORKS.

4. A MINIMUM CLEARANCE OF 0.5 METER MUST BE PROVIDED BETWEEN THE UNDERSIDE OF THE PROPOSED WORKS AND THE TOP OF ANY EXISTING WATERMAIN OR SEWERMAIN.

5. A MINIMUM CLEARANCE OF 2.0 METERS MUST BE PROVIDED BETWEEN ANY EXISTING WATERMAIN OR SEWERMAIN PIPE AND THE PROPOSED WORKS.

6. CONTACT THE CUSTOMER TECHNICAL SERVICES BRANCH AT 986-3322 48 HOURS PRIOR TO CONSTRUCTION FOR CLEARANCE OF EXISTING WATER AND WASTEWATER UTILITIES.

CIVIL PLAN, GRADING PLAN & PROFILE - NORTH				
Drawing	Title			
10 cierce	HILDE THO FRA CR	RMAN MAS NK		
	Landscape Archit	ecture • Planning		
500 Tel	0-115 Bannatyne Avenue East, lephone 204 • 944 • 9907	Winnipeg, Manitoba R3B 0R3 Facsimile 204 • 957 • 1467		
Drawn	AJH	Approved GM		
Scale	HOR 1:100 VER 1:10	JUNE 3, 2010		

09 048

Drawing L-3.2